



APPLICATION FOR APPEAL

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

RECEIVED

APR 14 2011

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:
Tuesday, <u>4-26-11</u>
Time <u>1:30</u>
Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1123 Minnehaha Ave. City: ST Paul State: MN Zip: 55106

Appellant/Applicant: Jim Fitzenberger Email _____

Phone Numbers: Business _____ Residence 738-2815 Cell _____

Signature: _____ Date: _____

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

RECEIVED
APR 14 2011
CITY CLERK

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 3-17-11

APPEAL PROPERTY ADDRESS: 1123 Minnehaha W.

APPLICANT NAME: Jim E. Fitzenbarger PHONE NUMBER: 651-738-2815

PERMIT NUMBER: 2011-007106

TYPE OF WINDOW: Double Hung

NUMBER OF WINDOWS: 1

TOTAL GLAZED AREA: 6.5 sq ft

DIFFERENCE FROM REQUIRED AREA: + 1.5 sq ft

WIDTH OF OPENING: 20"

DIFFERENCE FROM REQUIRED OPENING: 0

HEIGHT OF OPENING: 20"

DIFFERENCE FROM REQUIRED OPENING: - 4"

HEIGHT OF OPENING TO FINISHED FLOOR: 27"

DIFFERENCE FROM MAXIMUM HEIGHT: - 21"

COMMENTS: _____

FROM: Ken Eggen

\$25.00