



Gary Blair <gary.carpetcourt@gmail.com>

---

## Meter Protection questioned for 1820 Stillwater Ave E, St Paul

1 message

---

**Schmidt, Jeffrey J** <jeffrey.j.schmidt@xcelenergy.com>

Mon, Jul 13, 2015 at 1:37 PM

To: "gary@carpetcourt.com" <gary@carpetcourt.com>

Cc: "McGinnis, Christine M" <Christine.McGinnis@xcelenergy.com>, "Bahr, Tyler J" <Tyler.J.Bahr@xcelenergy.com>

Gary,

I reviewed this site and determined protection is not required at this time with no true driving surface present and protection is currently provided by Cedar Tree and building wall.

**Jeffrey Schmidt**

**Xcel Energy | Responsible By Nature**

Supervisor, Field Operations

825 Rice Street, 1st Floor Saint Paul, MN 55117

P: 651-229-2381 Pager:612-530-5168 F: 651-229-2396E: [jeffrey.j.schmidt@xcelenergy.com](mailto:jeffrey.j.schmidt@xcelenergy.com)

---

**XCELENERGY.COM**

Please consider the environment before printing this email