



APPLICATION FOR APPEAL

RECEIVED

JUN 03 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, June 21, 2011

Time 1:30 p.m.

Location of Hearing:

Room 330 City Hall/Courthouse

e-mailed 6-3-11

Address Being Appealed:

Number & Street: 1061 Pleasant Ave City: St. Paul State: MN Zip: 55102

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersenecorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): Roger Krenner

Address (if not Appellant's): 1061 Pleasant Ave St. Paul, MN 55102

Phone Numbers: Business _____ Residence 651-222-2021 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing to replacement windows that will not comply w/ St. Paul Egress policy. The current windows are short by no more than 6" in height and are compliant w/ minimal allowed width. Please Approve.

W S & D Permit Service
9533 - 367th Street
North Branch, MN 55056

Revised 8/20/2010



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: May 31, 2011

APPEAL PROPERTY ADDRESS: 1061 PLEASANT AVE

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 11 148462

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 2

Total Glazed Area Minimum 5 Square Feet	9.9	Difference from Required Area	+4.9
Width of Opening Minimum 20 Inches	32	Difference from Required Opening	+12
Height of Opening Minimum 24 Inches	22	Difference from Required Opening	-2
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	36	Difference from Maximum Height	Ok

COMMENTS: With the information provided above, approval is recommended. 5-31-11 rr

Reviewed by: Rehn



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: May 31, 2011

APPEAL PROPERTY ADDRESS: 1061 PLEASANT AVE
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-264-4914
PERMIT NUMBER: 11 148462
TYPE OF WINDOW: Double Hung
NUMBER OF WINDOWS: 4

Total Glazed Area Minimum 5 Square Feet	10.9	Difference from Required Area	+5.9
Width of Opening Minimum 20 Inches	32	Difference from Required Opening	+12
Height of Opening Minimum 24 Inches	18	Difference from Required Opening	-6
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	36	Difference from Maximum Height	Ok

COMMENTS: NA

Reviewed by: Rehn