



# APPLICATION FOR APPEAL

RECEIVED

JUN 03 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

\$25 filing fee payable to the City of Saint Paul  
(if cash: receipt number \_\_\_\_\_)

Copy of the City-issued orders or letter which  
are being appealed

Attachments you may wish to include  
 This appeal form completed

YOUR HEARING Date and Time:

Tuesday, June 21, 2011

Time 1:30 p.m.

Location of Hearing:

Room 330 City Hall/Courthouse

e-mailed 6-3-11

## Address BeingAppealed:

Number & Street: 1061 Pleasant Ave City: St. Paul State: MN Zip: 55102

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersoncorp.com

Phone Numbers: Business 651-264-4088 Residence \_\_\_\_\_ Cell \_\_\_\_\_

Signature: Bryan Horton Date: \_\_\_\_\_

Name of Owner (if other than Appellant): Roger Krenner

Address (if not Appellant's): 1061 Pleasant Ave St. Paul, MN 55102

Phone Numbers: Business \_\_\_\_\_ Residence 651-222-2021 Cell \_\_\_\_\_

## What Is Being appealed and why? *Attachments Are Acceptable*

Vacate Order/Condemnation/  
Revocation of Fire C of O

Summary/Vehicle Abatement

Fire C of O Deficiency List

Fire C of O: Only Egress Windows

Code Enforcement Correction Notice

Vacant Building Registration

Other

Other

Other

We are appealing to replacement windows  
that will not comply w/ St. Paul Egress  
policy. The current windows are short by  
no more than 6" in height and are  
compliant w/ minimal allowed width.  
Please Approve.

WS & D Permit Service  
9533 - 367th Street  
North Branch, MN 55056

Revised 8/20/2010



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: May 31, 2011

APPEAL PROPERTY ADDRESS: 1061 PLEASANT AVE

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 11 148462

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 2

Total Glazed Area Minimum 5 Square Feet	9.9	Difference from Required Area	+4.9
Width of Opening Minimum 20 Inches	32	Difference from Required Opening	+12
Height of Opening Minimum 24 Inches	22	Difference from Required Opening	-2
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	36	Difference from Maximum Height	Ok

COMMENTS: With the information provided above, approval is recommended. 5-31-11 rr

Reviewed by: Rehn



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: May 31, 2011

APPEAL PROPERTY ADDRESS: 1061 PLEASANT AVE

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 11 148462

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 4

Total Glazed Area Minimum 5 Square Feet	10.9	Difference from Required Area	+5.9
Width of Opening Minimum 20 Inches	32	Difference from Required Opening	+12
Height of Opening Minimum 24 Inches	18	Difference from Required Opening	-6
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	36	Difference from Maximum Height	Ok

COMMENTS: NA

Reviewed by: Rehn