



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

RECEIVED

JAN 23 2012

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:

Tuesday, 2-7-12

Time 1:30 p.m.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1586 Montana Ave E City: St. Paul State: MN Zip: 55106

Appellant/Applicant: Merit Building Co. Email merit@meritbuildingco.com

Phone Numbers: Business 763-323-7363 Residence _____ Cell _____

Signature: Gayle Aman Date: 1-20-12

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

See attachment



ORIGINAL

CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: January 18, 2012

APPEAL PROPERTY ADDRESS: 1586 MONTANA AVE E

APPLICANT NAME: MERIT BUILDING COMPANY INC

PHONE NUMBER: 763-323-7363

PERMIT NUMBER: 11 276866

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS Three

Total Glazed Area Minimum 5 Square Feet	10.8 sq. ft. 8.0 sq. ft. 12.9 sq.ft.	Difference from Required Area	+5.1sq.ft. +2.3sq.ft. +7.2sq.ft.
Width of Opening Minimum 20 Inches	34" 24" 36"	Difference from Required Opening	+14" +4" +16"
Height of Opening Minimum 24 Inches	18" 19" 19"	Difference from Required Opening	-6" -5" -5'
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	All OK	Difference from Maximum Height	

COMMENTS:

Reviewed by: 
David D. Nelson

JAN 19 2012