



APPLICATION FOR APPEAL

RECEIVED

JUN 08 2012

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☐ \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____) Request fee waiver for SMRLS
- ☒ Copy of the City-issued orders or letter which are being appealed
- ☐ Attachments you may wish to include
- ☒ This appeal form completed
- ☒ Walk-In OR ☐ Mail-In

YOUR HEARING Date and Time:

Tuesday, June 19, 2012

Time 11:00 a.m.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1155 7th St W. City: St. Paul State: MN Zip: 55102

Appellant/Applicant: Dominiques Perkins Apt #3 Email: lisa.hollingsworth@smrls.org

Phone Numbers: Business 651-222-5863 Residence _____ Cell 612-385-0245-tenant

Signature: [Signature] Date: 6/8/12

Name of Owner (if other than Appellant): Chris Deuth

Address (if not Appellant's): 1349 Robert St. S. #201, West St. Paul MN 55118

Phone Numbers: Business 651-341-5551 Residence _____ Cell _____

What Is Being Appealed and Why?

Attachments Are Acceptable

- ☒ Vacate Order/Condemnation/Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☐ Fire C of O Deficiency List
- ☐ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other

None of the repairs listed in the 6/1/12
revocation of certificate of occupancy & order
to vacate are life/safety or tenant-caused
issues. In fact, none of the items relate
to the interiors of the units at all. The
tenants in the building report being very
happy and would like to remain there.

I spoke to the owner, and he is
willing to work with DSI to resolve outstanding
issues.

Revised 3/7/2011



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

June 1, 2012

CHRIS DEUTH
1349 ROBERT ST S # 201
WEST ST PAUL MN 55118

Revocation of Fire Certificate of Occupancy and Order to Vacate

RE: 1155 7TH ST W
Ref. # 79737

Dear Property Representative:

Your building was determined to be a registered vacant building on June 1, 2012. Since certificates are for the occupancy of buildings, it has become necessary to revoke the Certificate of Occupancy.

Saint Paul Legislative Code provides that no building shall be occupied without a Certificate of Occupancy. In order to re-occupy the building, the following deficiencies (if applicable) must be corrected and a complete Certificate of Occupancy inspection will be required.

DEFICIENCY LIST

1. Exterior - Front - SPLC 71.01 - The address posted is not visible from street. (HN-1)- Provide reflective numbers or background or illuminate at night.
2. Exterior - Front Retaining Wall - SPLC 34.08 (5), 34.31 (3) - Repair, replace and maintain all exterior surfaces on fences, sheds, garages and other accessory structures free from holes and deterioration. Provide and maintain exterior unprotected surfaces painted or protected from the elements.-Repair deteriorated concrete retaining wall in an approved manner.
3. Exterior - Northeast - UMC 504.6 - Repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work may require a permit(s). Call DSI at (651) 266-8989.- Repair or replace damaged dryer vent back-draft damper and vent in an approved manner.

4. Exterior - Rear - SPLC 34.08 (3) - Provide and maintain suitable ground cover on all exterior areas to control erosion.
5. Exterior - Throughout - SPLC 34.09 (1) b,c, 34.32 (1) b,c - Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint.-
Scrape and paint as needed wherever chipped or peeling or wood is exposed on trim, windows, siding, porches, railing, soffit, fascia and other surfaces.
Repair holes and damaged areas of the soffit and fascia in a professional manner.
Replace rotting and deteriorated wood as necessary throughout exterior.
Repair cracking and deterioration to foundation as necessary in an approved manner.
6. Exterior - Throughout - SPLC 34.09 (3), 34.32 (3) - Repair and maintain the window frame.
7. Exterior - Throughout - SPLC 34.12 (2), 34.35 (1) - Repair and maintain all required and supplied equipment in an operative and safe condition.-Repair or replace all damaged and disconnected gutters and downspouts.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: mitchell.imbertson@ci.stpaul.mn.us or call me at 651-266-8986 between 7:30 - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Mitchell Imbertson
Fire Inspection

Ref. # 79737