



# APPLICATION FOR APPEAL

RECEIVED  
AUG 10 2011  
CITY CLERK

Saint Paul City Clerk  
310 City Hall, 15 W. Kellogg Blvd.  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number 517051)
- Copy of the City-issued orders or letter which are being appealed
  - Attachments you may wish to include
- This appeal form completed
- Walk-In OR  Mail-In

YOUR HEARING Date and Time:

Tuesday, August 23, 2011

Time 1:30 p.m.

Location of Hearing:

Room 330 City Hall/Courthouse

## Address Being Appealed:

Number & Street: 764 E. MARYLAND City: ST. PAUL State: MN Zip: 55106

Appellant/Applicant: JEFF NOREEN Email \_\_\_\_\_

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell 651.238.3373

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Name of Owner (if other than Appellant): JEFF NOREEN

Address (if not Appellant's): 768 E. MARYLAND

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell \_\_\_\_\_

## What Is Being Appealed and Why?

*Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

DENIED PERMIT



CITY OF SAINT PAUL

Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Telephone: 651-266-8989  
Saint Paul, MN 55101-1806 Fax: 651-266-8951

July 29, 2011

JEFF NOREEN  
768 MARYLAND AVE E  
ST PAUL MN 55106-2539

**FIRE CERTIFICATE OF OCCUPANCY  
APPROVAL WITH CORRECTIONS**

RE: 764 MARYLAND AVE E  
Ref. # 106965

Dear Property Representative:

Your building was inspected on July 29, 2011 for the renewal of the Fire Certificate of Occupancy and was approved. When the required fee has been paid you will receive your certificate. There are however seasonal or non-life safety deficiencies noted below which must be corrected prior to re-inspection.

DEFICIENCY LIST

4:30 375 JACKSON

1. Basement - UMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work may require a permit(s). .PERMIT REQUIRED. and inspection by Warm Air /Vent inspector Call 266-9006

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

For an explanation or information on some of the violations contained in this report, please visit our web page at: <http://www.ci.stpaul.mn.us/index.aspx?NID=211>

If you have any questions, email me at: [mike.cassidy@ci.stpaul.mn.us](mailto:mike.cassidy@ci.stpaul.mn.us) or call me at 651-266-8984 between 7:30 a.m - 9:00 a.m.

Sincerely,

Mike Cassidy  
Fire Inspector

Ref. # 106965