



APPLICATION FOR APPEAL

RECEIVED

JUL 05 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 7-26-11

Time 1:30

Location of Hearing:
Room 330 City Hall/Courthouse

September 7-5-11

Address Being Appealed:

Number & Street: 1226 BERKELEY AVE City: ST. PAUL State: MN Zip: 55105

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: *[Signature]* Date: _____

Name of Owner (if other than Appellant): Elizabeth & Paul Cheslik

Address (if not Appellant's): 1226 Berkeley Ave St. Paul MN 55105

Phone Numbers: Business _____ Residence 715-410-3189 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 4 double hung and 2 gliding window replacements that will not comply w/ St. Paul Uniform Egress policy. Double Hungs are short in operable height but exceed all other criteria. Gliding windows will be short in operable width but exceed all other criteria. Please Approve.

Revised 8/20/2010



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: June 27, 2011

APPEAL PROPERTY ADDRESS: 1226 BERKELEY AVE
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-264-4914
PERMIT NUMBER: 11 244194
TYPE OF WINDOW: Double Hung
NUMBER OF WINDOWS: 4

Total Glazed Area Minimum 5 Square Feet	12	Difference from Required Area	+7
Width of Opening Minimum 20 Inches	28	Difference from Required Opening	+8
Height of Opening Minimum 24 Inches	23.125	Difference from Required Opening	-.875
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	36	Difference from Maximum Height	ok

COMMENTS: With the information provided above approval is recommended. 6-27-11 rr

Reviewed by: Rehn



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: June 27, 2011

APPEAL PROPERTY ADDRESS: 1226 BERKELEY AVE
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-264-4914
PERMIT NUMBER: 11 244194
TYPE OF WINDOW: Slider
NUMBER OF WINDOWS: 2

Total Glazed Area Minimum 5 Square Feet	15	Difference from Required Area	+10
Width of Opening Minimum 20 Inches	18	Difference from Required Opening	-2
Height of Opening Minimum 24 Inches	44	Difference from Required Opening	+20
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	36	Difference from Maximum Height	ok

COMMENTS: With the information provided above approval is recommended. 6-27-11 rr

Reviewed by: Rehn