



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

No. 0443 P. 6

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: 4-24-12

APPEAL PROPERTY ADDRESS: 301 GOODRUE # 1 E # 2

APPLICANT NAME: PUBLIC HEALTH (DANIEL SCHMIDT) PHONE NUMBER: 266-1143

PERMIT NUMBER: \_\_\_\_\_

TYPE OF WINDOW: DOUBLE HUNG

NUMBER OF WINDOWS: 2 (1 in each unit)

TOTAL GLAZED AREA: (9.7 sq ft) i (9.1 sq ft) DIFFERENCE FROM REQUIRED AREA: COMP

WIDTH OF OPENING: (25") i (23") DIFFERENCE FROM REQUIRED OPENING: COMP

HEIGHT OF OPENING: 22" DIFFERENCE FROM REQUIRED OPENING: 2"

HEIGHT OF OPENING TO FINISHED FLOOR: 248" DIFFERENCE FROM MAXIMUM HEIGHT: Comp

RECOMMENDATION (IF APPLICABLE): \_\_\_\_\_

RECEIVED

APR 24 2012

CITY CLERK

FROM: \_\_\_\_\_

Apr. 24. 2012 1:16PM

No. 0443 P. 7

St Paul-Ramsey Co. Public Health

Apr. 24. 2012 1:16PM

Select a Model  
 (Model 0201)

Top Sash Width	26.2500	Min. W: 11	Max. W: 52	Max. U: 132
Top Sash Height	27.1875	Min. H: 10	Max. H: 84	
Bottom Sash Width	27.2500	Exact Size		
Bottom Sash Height	28.1875	Width: 29.5	29.5	
Top Glass Width	24.9625	Height: 57.5	57.5	
Top Glass Height	26.6000	Extrusion: <input type="text" value="Select Extrusion"/> << For Arch-Top Models Only		
Bottom Glass Width	25.5625	Opening: <input type="text" value="Exact Size"/>		
Bottom Glass Height	26.5000	Type: <input type="text" value="Standard"/>		
Screen Width	25.8125	Screen: <input type="text" value="Full"/>		
Screen Height	54.0250	Glass: <input type="text" value="Double Strength (3 mm)"/>		
Top Sash Weight (Plus 5 lb)	22 lb	<input type="checkbox"/> AC Sash Calculator		
Top Balance Size (C.F.)	56BU			
Top Balance Size (Spiral)	23-9R			
Bottom Sash Weight	13 lb			
Bottom Balance Size (C.F.)	5NAT			
Bottom Balance Size (Spiral)	27-1R			
Egress Opening Width	25.0940			
Egress Opening Height	22.0000			
Egress Opening Area (sq.ft.)	3.6340			

301 GOODHUE #1