



APPLICATION FOR APPEAL

RECEIVED

SEP 20 2011

CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:	
Tuesday,	<u>10-4-11</u>
Time	<u>1:30</u>
Location of Hearing:	
<u>Room 330 City Hall/Courthouse</u>	

emailed 9-20-11

Address Being Appealed:

Number & Street: 176 Otis Ave City: St. Paul State: MN Zip: 55105

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): Cennie Smith

Address (if not Appellant's): 176 Otis Ave St. Paul, MN 55105

Phone Numbers: Business _____ Residence (507)-282-7936 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 2 bedroom windows that will not comply w/ St. Paul Egress Policy. Height on both Double hungs will be shorter than minimum required. Openable width and overall glazed criteria is met. Homeowner does not want to change operating style. Please Approve.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: September 15, 2011

APPEAL PROPERTY ADDRESS: 176 OTIS AVE

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 11 276363


TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 1

Total Glazed Area Minimum 5 Square Feet	5.6 sq. ft.	Difference from Required Area	+ .6 sq. ft.
Width of Opening Minimum 20 Inches	24"	Difference from Required Opening	+4"
Height of Opening Minimum 24 Inches	16 7/8"	Difference from Required Opening	-7 1/8"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	Ok	Difference from Maximum Height	ok

COMMENTS:

Reviewed by: DD 9-15-11



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: September 15, 2011

APPEAL PROPERTY ADDRESS: 176 OTIS AVE

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 11 276363

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 1

Total Glazed Area Minimum 5 Square Feet	6.2 sq. ft.	Difference from Required Area	+1.2 sq. ft
Width of Opening Minimum 20 Inches	24"	Difference from Required Opening	+4"
Height of Opening Minimum 24 Inches	18"	Difference from Required Opening	-6"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	Ok	Difference from Maximum Height	ok

COMMENTS:

Reviewed by: DD 9-15-11