



APPLICATION FOR APPEAL

Saint Paul City Council – Legislative Hearings

310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8585

RECEIVED

FEB 03 2014

CITY CLERK

We need the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number Check 5152)
 - Copy of the City-issued orders/letter being appealed
 - Attachments you may wish to include
 - This appeal form completed
 - Walk-In OR Mail-In
- for abatement orders only: Email OR Fax

HEARING DATE & TIME (provided by Legislative Hearing Office) Tuesday, <u>February 11, 2014</u> Time <u>1:30 p.m.</u> Location of Hearing: Room 330 City Hall/Courthouse

e-mailed 2/13/14

Address Being Appealed:

Number & Street: 1370 E. Arlington Ave City: St. Paul State: MIN Zip: 55106

Appellant/Applicant: Alexandra Golovko Email: alexinc3@gmail.com

Phone Numbers: Business 651-274-8187 Residence 651-274-8187 Cell 651-274-8187

Signature: Alexandra Golovko Date: 1/29/14

Name of Owner (if other than Appellant): Mary Shayda - my mom

Mailing Address if Not Appellant's: 856 Woodland Court Saint Paul, MN 55115

Phone Numbers: Business 651-274-8187 Residence 651-274-8187 Cell 651-274-8187

What Is Being Appealed and Why? Attachments Are Acceptable

- Vacate Order/Condemnation/ Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

I am appealing the Correction Notice - Daycare Inspection (attached). Appealing the Three Bedroom Egress Windows. Only one bedroom will be used for toys, books etc and dresser for childrens extra clothes, mittens hats, gloves etc. Children will sleep on cot in the living room - will be the play area too. Children will not be sleeping in our bedrooms.



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Telephone: 651-266-8989
Saint Paul, MN 55101-1806 Fax: 651-266-8951

January 21, 2014

ALEXANDRA GOLOVKO
1370 ARLINGTON AVE E
ST PAUL MN 55106

CORRECTION NOTICE – DAY CARE INSPECTION

RE: 1370 ARLINGTON AVE E

Dear Property Representative:

A re-inspection was made on your building on January 21, 2014, in response to a complaint. You are hereby notified that the following deficiencies must be corrected prior to re-inspection date. **A re-inspection will be made on February 18, 2014 at 10:00AM.**

DEFICIENCY LIST

1. BASEMENT STAIRS - REMOVE STORAGE - MSFC 104.9, 1005.3.2.2 - Remove the storage under the stairs or provide and maintain 1 hour fire resistive construction on the storage side of the stairs.
2. DAYCARE AND BEDROOM WINDOWS - MAKE OPERATIONAL - MSFC 703 - The fire window must not be obstructed or impaired from its proper operation at any time.-Ensure that the west living room window and all bedroom windows are unfrozen and are openable from the inside.
3. KITCHEN - MOUNT FIRE EXTINGUISHER - MSFC 906.1, MN Stat. 299F.361-Mount the 2A10BC fire extinguisher in the kitchen. It must be permanently mounted between 3 and 5 feet high in readily visible and easily accessible location.
4. ***THREE BEDROOM EGRESS WINDOWS - OPENABLE DIMENSIONS - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651) - 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-Three bedrooms each have egress windows with the openable dimensions of 18 inches high by 33 inches wide.**
5. TWO LOCATIONS - PROVIDE THUMB TURN LOCKS - MSFC 1003.3.1.8 - Remove unapproved locks from the exit doors. The door must be openable from the inside without the use of keys or special knowledge or effort.-Provide a thumb turn lock for the front door. Reverse the basement stairway lock so it is openable from the downstairs side.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>.

***You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, St Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.**

If you have any questions, email me at james.perucca@ci.stpaul.mn.us or call me at 651-266-8996 between 7:30 a.m - 9:00 a.m.

Please help to make Saint Paul a safer city in which to live and work.

Sincerely,

James Perucca
Fire Inspector