



APPLICATION FOR APPEAL

Saint Paul City Clerk
15 W. Kellogg Blvd., 310 City Hall
Saint Paul, Minnesota 55102
Telephone: (651) 266-8688

RECEIVED
OCT 08 2010
CITY CLERK

1. Address of Property being Appealed: 652 E. Concord Street	2. Number of Dwelling Units: 01	3. Date of Letter Appealed: October 6th 2010
--	---	--

4. Name of Owner: **William E. Goldberg**

Address: **1254 S. Robert St** City: **WSTPaul,** State: **Mn.** Zip: **55118**

Phone Numbers: Business **651-457-9111** Residence **651-450-0410** Cellular **612-325-9856**

Signature: *[Handwritten Signature]*

5. Appellant / Applicant (if other than owner): **same as above**

Address: _____ City: _____ State: _____ Zip: _____

Phone Numbers: Business _____ Residence _____ Cellular _____

Signature: _____

6 State specifically what is being appealed and why (Use an attachment if necessary):

1935+vintage 1 1/2 story remodeled house being occupied asap

wood frame 2 bedroom house each bedroom has two or more easy

stucco house exit double hung windows. However newer vinyl

total up- replacement d.h. inserts windows changed slightly

dated remodel. egress/agress sizing. Exterior of house is stucco,

windows are balanced even on each side wall exterior.

Part of this remodel included full compliance smoke

protectors w/carbon/hard wired w/batt backups, one in

each bedroom plus adjacent hallway and lower level as well.

NOTE: A \$25.00 filing fee made payable to the City of Saint Paul must accompany this application as a necessary condition for filing. You must attach a copy of the original orders and any other correspondence relative to this appeal. Any person unsatisfied by the final decision of the City Council may obtain judicial review by timely filing of an action as provided by law in District Court.

* in series) (all hard wi

For Office Use Only

Date Received: 10-8-10	Fee Received: 25.00	Receipt Number: —	Date of Hearing: Oct. 19, 2010 1:30 p.m.
----------------------------------	-------------------------------	-----------------------------	--

330 CH



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: September 30, 2010

APPEAL PROPERTY ADDRESS: 652 CONCORD ST

APPLICANT NAME: WILLIAM E GOLDBERG

PHONE NUMBER: 651-266-9046

PERMIT NUMBER: 09 266734

TYPE OF WINDOW DH

NUMBER OF WINDOWS 2 both the same

Total Glazed Area	8	Difference from Required Area	+3
Width of Opening	24.75	Difference from Required Opening	+4.75
Height of Opening	20.5	Difference from Required Opening	_3.5
Height of Opening to Finished Floor	(28")	Difference from Maximum Height	-----

COMMENTS:

Reviewed by: