



APPLICATION FOR APPEAL

Saint Paul City Council – Legislative Hearings

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8585

RECEIVED

APR 15 2013

CITY CLERK

We need the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number 351939)
 - Copy of the City-issued orders/letter being appealed
 - Attachments you may wish to include
 - This appeal form completed
 - Walk-In OR Mail-In
- for abatement orders only: Email OR Fax

HEARING DATE & TIME
(provided by Legislative Hearing Office)
Tuesday, <u>April 16, 2013</u>
Time <u>11:30 a.m.</u>
Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 152 UNIVERSITY AVE W City: ST. PAUL State: MN Zip: 55103

Appellant/Applicant: JENNIFER JAHANGIR
ST. PAUL TOBACCO ROOM Email lejens35@hotmail.com

Phone Numbers: Business 651-334-8888 Residence - Cell -

Signature: Jennifer Jahangir Date: 4.15.13

Name of Owner (if other than Appellant): _____

Mailing Address if Not Appellant's: 15477 FROSS PATH, Apple Valley MN 55124

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O CONDEMNATION OF BUILDING
- Summary/Vehicle Abatement _____
- Fire C of O Deficiency List _____
- Code Enforcement Correction Notice _____
- Vacant Building Registration _____
- Other _____



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

April 8, 2013

JB REALTY CO
2557 MAPLEWOOD DRIVE
ST PAUL MN 55109

**NOTICE OF CONDEMNATION
UNFIT FOR HUMAN HABITATION
ORDER TO VACATE**

RE: 152 UNIVERSITY AVE W
Ref. # 61347

Dear Property Representative:

Your building was inspected on April 8, 2013.

The building was found to be unsafe, unfit for human habitation, a public nuisance, a hazard to the public welfare or otherwise dangerous to human life. A Condemnation Placard has been posted on the building.

The following deficiency list must be completed or the building vacated by the re-inspection date.

A reinspection will be made on or after April 9, 2013.

CONDEMNATION OF THE BUILDING REVOKES THE CERTIFICATE OF OCCUPANCY.

Failure to complete the corrections may result in a criminal citation. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy.

DEFICIENCY LIST

1. BUILDING - SPLC 34.23, MSFC 110.1 - This occupancy is condemned as unsafe or dangerous. This occupancy must not be used until re-inspected and approved by this office.

Building is condemned as unsafe due to the following conditions;

- Rear staircase is structurally unsound.**
- Front and rear parapets are severely deteriorated creating a dangerous condition.**
- The sidewalk in the front of the building was closed off.**

-The required second exit for the business cannot be used due to the exit being in direct line with the damaged parapet.

2. EXTERIOR - PARAPETS - SPLC 34.09 (1) b,c, 34.33 (1) b, c - Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint. **-Front and rear parapets have loose bricks and deteriorated mortar. Bricks are ready to fall onto the pedestrian walkways, tracks and street below.**
3. EXTERIOR - REAR STAIRS - SPLC 34.09 (2), 34.32(2) - Repair or replace the unsafe stairways, porch, decks or railings in an approved manner. This work may require a permit(s). Call DSI at (651) 266-9090. **-Rear stairs have rotted wood, nails popping, and damaged structural members.**
4. EXTERIOR - ROOF - SPLC 34.09 (1) e, 34.32 (1) d - Provide and maintained the roof weather tight and free from defects. **-Rubber membrane of roof is cracked and damaged. -Roof is very spongy.**
5. EXTERIOR - SPLC 163.03, 163.01 (2), (3) - Currently license (tabs) all vehicles on the property and return the vehicles to an operative mechanical condition or remove vehicles from the property.
6. INTERIOR - SPLC 34.19 - Provide access to the inspector to all areas of the building.
7. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
8. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at: adrian.neis@ci.stpaul.mn.us or call me at 651-266-8992 between 7:30 - 9:00 a.m. Please help make Saint Paul a safer place in which to live and work.

Sincerely,

A.J. Neis
Fire Inspector
Ref. # 61347

cc: Housing Resource Center
Force Unit