



APPLICATION FOR APPEAL

Saint Paul City Council – Legislative Hearings

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8585

RECEIVED

SEP 11 2013

CITY CLERK

We need the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number 351 986)
- ☒ Copy of the City-issued orders/letter being appealed
- ☐ Attachments you may wish to include
- ☒ This appeal form completed
- ☒ Walk-In OR ☐ Mail-In
for abatement orders only: ☐ Email OR ☐ Fax

HEARING DATE & TIME

(provided by Legislative Hearing Office)

Tuesday, 9-17-13

Time 1:30 PM

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 598 Capitol Blvd City: St Paul State: MN Zip: 55103

Appellant/Applicant: Emily Sundseth Email: esundseth@comcast.net

Phone Numbers: Business 651-738-5881 Residence _____ Cell 651-248-5826

Signature: [Signature] Date: 9.11.13

Name of Owner (if other than Appellant): _____

Mailing Address if Not Appellant's: 1750 Ames Pl, St Paul, MN 55106

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? Attachments Are Acceptable

- ☐ Vacate Order/Condemnation/Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☒ Fire C of O Deficiency List
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other

#3. SPLC 34.08(7) paving of parking space. Parking has never been paved and is a defined and clean space with a driveway built into the curb



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

August 22, 2013

SCOTT E ALBRIGHT
EMILY I SUNDSETH
1750 AMES PL
ST PAUL MN 55106-2954

FIRE INSPECTION CORRECTION NOTICE

RE: 598 CAPITOL BLVD
Ref. #115411
Residential Class: C

Dear Property Representative:

Your building was inspected on July 25, 2013 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

A re-inspection will be made on September 12, 2013 at 1:00 PM.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. Exterior - West Entry - SPLC 34.09 (2) 34.32 (2) - Provide an approved handrail. The top of the handrail must be between 34 and 38 inches above the treads and run the entire length of the stair.
2. Exterior - West Entry - SPLC 34.09 (2) 34.32 (2) - Provide an approved guardrail with intermediate balustrade or rails 4 inches or less apart. This work may require a permit(s). Call DSI at (651) 266-9090.

3. Exterior - SPLC 34.08 (7) - All parking spaces shall be paved with asphalt, concrete, or durable dustless surfacing. Before any existing spaces may be paved, site plan approval must be obtained as specified in the St. Paul Zoning Code. Contact DSI Zoning at 651-266-9090.
4. Interior - Basement - MN Stat. 299F.362 - Immediately provide and maintain a smoke detector located outside each sleeping area. - Replace smoke alarm and batteries in basement.
5. Interior - Entryway - MSFC 3404.3.3.3 - Class 1, 2, and 3A Flammable/Combustible liquids must not be stored near or be allowed to obstruct physically the route of egress. - Remove gas can from front entry way.
6. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
7. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: jeremy.hall@ci.stpaul.mn.us or call me at 651-266-8987 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Jeremy Hall
Fire Inspector

Reference Number 115411