



APPLICATION FOR APPEAL

RECEIVED

NOV 15 2010

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 11/30/10

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1361 ST. ALBANS ST. City: ST. PAUL State: MN Zip: 55117

Appellant/Applicant: DAN BYDLON Email DAN@CHI-SERVICE.COM

Phone Numbers: Business 651-430-2244 Residence _____ Cell _____

Signature: *Daniel J. Jolly* Date: 11-12-10

Name of Owner (if other than Appellant): ALAYNE THORESON

Address (if not Appellant's): SAME

Phone Numbers: Business _____ Residence _____ Cell 651-231-4562

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration

- Other
- Other
- Other

EGRESS WINDOW COMPLIANCE



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: November 2, 2010

APPEAL PROPERTY ADDRESS: 1361 ST ALBANS ST N

APPLICANT NAME: CRAFTSMEN HOME IMPROVEMENTS INC

PHONE NUMBER: 651-266-9020

PERMIT NUMBER: 10 614696

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 3 bedrooms

Total Glazed Area	1&2 9 sq. ft.	Difference from Required Area	+4 sq.ft. ok
	3 7 sq. ft.		+2 sq. ft. ok
Width of Opening	1&2 32"	Difference from Required Opening	+12"
	3 24"		+4"

Height of Opening	1&2 21"	Difference from Required Opening	-3"
	3 21"		-3"
Height of Opening to Finished Floor	1&2 28"	Difference from Maximum Height	+20"ok
	3 28"		+20"ok

COMMENTS:

Reviewed by: David Tank