



June 12, 2025

Connie M Baehr
961 Arcade St
Saint Paul MN 55106-3229

RE: RE-INSPECTION FIRE CERTIFICATE OF OCCUPANCY WITH DEFICIENCIES
961 ARCADE ST

Ref. # 14757

Dear Property Representative:

Your building was re-inspected for the Fire Certificate of Occupancy on June 6, 2025. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected immediately. **A reinspection will be made in accordance with updated deadlines following the legislative appeal result.**

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

DEFICIENCY LIST

1. Basement - SPLC 34.09 (2)(a), 34.33 (1)(a) - Provide and maintain foundation elements to adequately support this building at all points. - *Repair foundation deterioration as necessary in order to prevent water coming from foundation into the basement.*
2. Basement - SPLC 34.10 (7), 34.17 (5) - Repair and maintain the walls in an approved manner.
3. Basement - SPLC 34.10 (7), 34.17 (5) - Repair and maintain the ceiling in an approved manner. - *Patch as necessary in damaged and falling areas.*
4. Basement - SPLC 34.10 (1) - Abate and maintain the basement reasonably free from dampness and free of mold and mildew.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at mitchell.imbertson@ci.stpaul.mn.us or call me at 651-266-8986 between 7:30 a.m - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Mitchell Imbertson
Fire Safety Inspector
Ref. # 14757