



APPLICATION FOR APPEAL

RECEIVED

MAR 27 2012

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 4-3-12

Time 1:30 P.M.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 812 Fairmount Ave City: St. Paul State: mn Zip: 55105

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): Marie Dotsoth

Address (if not Appellant's): 812 Fairmount Ave

Phone Numbers: Business _____ Residence ²⁹⁸ 651-698-0938 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are replacing 2 windows that will not comply w/ Egress Policy. Openings will be short in operable height by 4 1/8". The homeowners want to keep style consistent throughout the home. All windows in house are being proposed for replacement. Please Approve



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: March 23, 2012

APPEAL PROPERTY ADDRESS: 812 FAIRMOUNT AVE

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 12 036447

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 2

Total Glazed Area Minimum 5 Square Feet	5.3 sq. ft.	Difference from Required Area	+3 sq. ft.
Width of Opening Minimum 20 Inches	20"	Difference from Required Opening	-
Height of Opening Minimum 24 Inches	19 1/8 "	Difference from Required Opening	-4 7/8"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	ok	Difference from Maximum Height	ok

COMMENTS:

Reviewed by: DD 3-23-12