

✓ Seamed



APPLICATION FOR APPEAL

RECEIVED

MAY 02 2012

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____)
- ☒ Copy of the City-issued orders or letter which
are being appealed
- ☐ Attachments you may wish to include
- ☒ This appeal form completed
- ☐ Walk-In OR ☒ Mail-In

YOUR HEARING Date and Time:

Tuesday, 5-15-12

Time 1:30 P.M.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 429 Thomas City: St Paul State: MN Zip: 55102

Appellant/Applicant: JoDell Kline Email GRJO51@Live.com

Phone Numbers: Business _____ Residence _____ Cell 612 432 6611

Signature: JoDell Kline Date: 4-30-12

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): 130 E Arion St, St Paul, MN, 55118

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? *Attachments Are Acceptable*

- ☐ Vacate Order/Condemnation/
- ☐ Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☐ Fire C of O Deficiency List
- ☒ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other

The window (Egress) was replaced with
the exact measurements, which is 24 inches
shy of code, because this is a brick house
and would be very costly to increase
the opening. The windows do "pop out"
completely and then does measure 24".
I would request a variance on this
older, brick home.



CITY OF SAINT PAUL

Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

April 18, 2012

JODELL M KLINE
PATRICK M KLINE
130 ARION ST E
WEST ST PAUL MN 55118-1562

FIRE INSPECTION CORRECTION NOTICE

RE: 429 THOMAS AVE

Dear Property Representative:

Your building was inspected on April 18, 2012 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

A re-inspection will be made on May 17, 2012 at 9 AM.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. Exterior - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651) - 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information. The bedroom measured 22H x 21W with a brick exterior. The window was replaced without permits. This is a one bedroom home.
2. Exterior - MSFC 1011.2 - Remove the materials that cause an exit obstruction. Maintain a clear and unobstructed exitway.-Remove the fence blocking the egress window in the bedroom and remove furniture blocking the front door exit.
3. Exterior - SPLC 34.08 (1), 34.31 (1) - All exterior property areas shall be maintained free from any accumulation of refuse, garbage or feces.-Remove wood and dog feces from the yard.
4. Exterior - SPLC 34.09 (3), 34.32 (3) - Repair and maintain the door in good condition.-Repair or replace damaged storm doors.

5. Exterior - SPLC 34.09 (3), 34.32 (3) - Provide or repair and maintain the window screens.
6. Interior - SPLC 200.02 (a) No person shall own, harbor, keep or maintain in the City and dog over three months of age without a license. Provide written documentation of current license to the Fire Inspector. To obtain a dog license, contact DSI at 651-266-8989
7. Interior-Throughout - MSFC 605.5 - Discontinue use of extension cords used in lieu of permanent wiring.
8. Interior-Throughout - MSFC 605.4 - Discontinue use of all multi-plug adapters.
9. Interior-Throughout - MSFC 605.1 - Repair or replace damaged electrical appliance wiring. This work requires a permit(s). Call DSI at (651) 266-9090.-Provide electric outlets for the stove, washer and dryer and throughout as needed.
10. Interior-Throughout - MSFC 315.2 - Remove the storage from attic or other concealed spaces or provide and maintain one hour fire resistive construction on the storage side of attics or other concealed spaces. Storage must not be placed on exposed joists.-Remove all storage from under the basement stairs.
11. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
12. SPLC 39.02(c) - Complete and sign the provided smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: lisa.martin@ci.stpaul.mn.us or call me at 651-266-8988 between 6:30 a.m. - 8:30 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Lisa Martin
Fire Inspector