



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

RECEIVED

AUG 25 2011

CITY CLERK

YOUR HEARING Date and Time:

Tuesday, 9-13-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

email 8-26-11

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

Address Being Appealed:

Number & Street: 522 Saratoga St S City: ST. PAUL State: MN Zip: _____

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: *[Handwritten Signature]* Date: _____

Name of Owner (if other than Appellant): Russell Klein

Address (if not Appellant's): 522 Saratoga St S

Phone Numbers: Business _____ Residence 651-492-3933 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 2 bedroom windows that will not comply w/ Egress Policy. The first bedroom will have a operable width of 28" and operable height of 19." The 2nd bedroom will have and operable width of 20" and an operable height of 19." Overall glazed area is met/exceeded on both openings. Please Approve



1

CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: August 22, 2011

APPEAL PROPERTY ADDRESS: 522 SARATOGA ST S
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-264-4914
PERMIT NUMBER: 11 266433
TYPE OF WINDOW Double Hung
NUMBER OF WINDOWS 1

Total Glazed Area Minimum 5 Square Feet	5.2	Difference from Required Area	+2
Width of Opening Minimum 20 Inches	20	Difference from Required Opening	Ok
Height of Opening Minimum 24 Inches	19	Difference from Required Opening	-5
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	<48	Difference from Maximum Height	OK

COMMENTS: NA

Reviewed by: Rehn



#2

CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: August 22, 2011

APPEAL PROPERTY ADDRESS: 522 SARATOGA ST S

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 11 266433

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 1

Total Glazed Area Minimum 5 Square Feet	7.4	Difference from Required Area	+2.4
Width of Opening Minimum 20 Inches	28	Difference from Required Opening	+8
Height of Opening Minimum 24 Inches	19	Difference from Required Opening	-5
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	<48	Difference from Maximum Height	ok

COMMENTS: NA

Reviewed by: Rehn