



APPLICATION FOR APPEAL

FCO

16-21

Saint Paul City Council – Legislative Hearings

RECEIVED

JAN 25 2016

CITY CLERK

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8585

We need the following to process your appeal:

- ☒ \$25 filing fee (non-refundable) (payable to the City of Saint Paul)
(if cash: receipt number 794642)
- ☒ Copy of the City-issued orders/letter being appealed
- ☐ Attachments you may wish to include
- ☒ This appeal form completed
- ☒ Walk-In OR ☐ Mail-In
- for abatement orders only: ☐ Email OR ☐ Fax

HEARING DATE & TIME

(provided by Legislative Hearing Office)

Tuesday, Feb 9

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

*Mr. Ving ok'd date in person
1/25*

Address Being Appealed:

Number & Street: 842 Feniks Ave City: St Paul State: MN Zip: 55106

Appellant/Applicant: _____ Email: _____

Phone Numbers: Business 651-666-7543 Residence _____ Cell 2

Signature: [Signature] Date: 1-25-16

Name of Owner (if other than Appellant): Ving Ving

Mailing Address if Not Appellant's: 2153 Beech St E St Paul MN 55119

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why?

Attachments Are Acceptable

- ☐ Vacate Order/Condemnation/
- ☐ Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☒ Fire C of O Deficiency List/Correction
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other (Fence Variance, Code Compliance, etc.)



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

January 21, 2016

YING VANG
CHEE XIONG
2153 BEECH ST
ST PAUL MN 55119

FIRE INSPECTION CORRECTION NOTICE

RE: 842 JENKS AVE
Ref. #104846
Residential Class: C

Dear Property Representative:

Your building was inspected on December 21, 2015 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. A re-inspection will be made on February 22, 2016 at 12:30 P.M..

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. 842 #1 - MSFC 605.6 - Provide electrical cover plates to all outlets, switches and junction boxes where missing. Room leading to the rear exit door.-
2. 842 #1 - SPLC 34.10 (4), 34.33 (3) - Provide a bathroom floor impervious to water. Caulk the base of the tub.-

3. 842 #1 - SPLC 34.13 (2), (3), SPLC 34.17 (2) - Reduce and maintain the number of occupants in the unit to: 2-Four 4 people over the age of 1 occupying 110 square feet.
4. 842 #1 - MSFC 1003.3.1.8 - Remove unapproved locks from the unit doors. The door must be openable from the inside without the use of keys or special knowledge or effort.-
5. Fence - SPLC 34.08(5), 34.32(3) - All accessory structures including, but not limited to, detached garages, sheds and fences shall be maintained structurally sound and in good repair. Provide and maintain exterior unprotected surfaces painted or protected from the elements.-
6. Front porch - SPLC 34.09 (2), 34.32(2) - Repair or replace the damaged guardrail in an approved manner. This work may require a permit(s). Call DSI at (651) 266-9090.-
7. Rear of Building - R404.5 Retaining walls. retaining walls that are not laterally supported at the top and that retain in excess of 24 inches of unbalanced fill shall be designed for safety factor.-

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: james.thomas@ci.stpaul.mn.us or call me at 651-266-8983 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas
Fire Inspector

Reference Number 104846