

Scanned

10/25-11
2:13:30



Saint Paul - Ramsey County Department of Public Health
Environmental Health Section
2785 White Bear Avenue North Suite 350
Maplewood, MN 55109-1320
FAX: (651) 266-1177

RECEIVED Date: 10-13-11
OCT 13 2011
CITY CLERK To FAX#: 6-8574

FACSIMILE TRANSMISSION
Cover Sheet and Transmittal Form

To: Mai Yang, Paralegal

Location: Legislative Hearing Office
City of St. Paul

Sender: Daniel Schmidt / Jim Yannarelli
St. Paul - Ramsey Cty. Dept. of Public Health

This transmission consists of 5 pages (including cover sheet).

If transmission is incomplete or illegible, call sender at (651) 266-1143 (DANIEL SCHMIDT)

Message:

Request for Egress Window Non-Compliance Determination

Attachments: Egress Window Non-Compliance Determination Form

674 Magnolia Ave. E.

CONFIDENTIALITY NOTICE

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8888
FAX: 651-266-8574

DATE: 10-13-11

APPEAL PROPERTY ADDRESS: 674 MAGNOLIA

APPLICANT NAME: PUBLIC HEALTH (DVA) PHONE NUMBER: 651-266-1143

PERMIT NUMBER: _____

TYPE OF WINDOW: DOUBLE HUNG VINYL

NUMBER OF WINDOWS: 1

TOTAL GLAZED AREA: 8.6 sqft

DIFFERENCE FROM REQUIRED AREA: COMPLIES

WIDTH OF OPENING: 19.2"

DIFFERENCE FROM REQUIRED OPENING: 1"

HEIGHT OF OPENING: 25.9"

DIFFERENCE FROM REQUIRED OPENING: COMPLIES

HEIGHT OF OPENING TO FINISHED FLOOR: 448"

DIFFERENCE FROM MAXIMUM HEIGHT: COMPLIES

RECOMMENDATION (IF APPLICABLE):

FROM: _____

Select a Model

(Model 0201)	0201
Excalibur Double Hung	
Top Sash Width	20.3750
Top Sash Height	31.1250
Bottom Sash Width	21.3750
Bottom Sash Height	32.0750
Top Glass Width	18.6875
Top Glass Height	29.4375
Bottom Glass Width	19.6875
Bottom Glass Height	30.3750
Screen Width	19.9375
Screen Height	62.4375
} TOTAL GLAZED	
Top Sash Weight (Plus 5 lb)	21 lb
Top Balance Size (C.F)	56BU
Top Balance Size (Spiral)	27-9R
Bottom Sash Weight	18 lb
Bottom Balance Size (C.F)	8NAT
Bottom Balance Size (Spiral)	30-9R
Egress Opening Width	19.2190
Egress Opening Height	25.9375
Egress Opening Area (sq.ft.)	3.4620

Min. W: 11	Max W: 52
Min. H: 20	Max H: 84
Max UI: 132	
Exact Size	
Width: 23.625	23.625
Height: 65.325	65.325
Extrusion: Select Extrusion	<< For Arch-Top Models Only
Opening: Exact Size	
Type: Standard	
Screen: Full	
Glass: Double Strength (3 mm)	

AC Sash Calculator

$$19.9 \times 62.4 = 1242 \div 144 = 8.6 \text{ sq ft}$$



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 10-13-11

APPEAL PROPERTY ADDRESS: 674 MAGNOLIA

APPLICANT NAME: PUBLIC HEALTH (DANIEL) PHONE NUMBER: 651-266-1143

PERMIT NUMBER: _____

TYPE OF WINDOW: Vinyl Double Hung

NUMBER OF WINDOWS: 1

TOTAL GLAZED AREA: 9.0 sq ft

DIFFERENCE FROM REQUIRED AREA: COMPLIES

WIDTH OF OPENING: 23.2"

DIFFERENCE FROM REQUIRED OPENING: COMPLIES

HEIGHT OF OPENING: 22"

DIFFERENCE FROM REQUIRED OPENING: 2"

HEIGHT OF OPENING TO FINISHED FLOOR: 248"

DIFFERENCE FROM MAXIMUM HEIGHT: COMPLIES

RECOMMENDATION (IF APPLICABLE): _____

FROM:

Select a Model

(Model 0201)		0201
Excalibur Double Hung		
Top Sash Width	24.3750	
Top Sash Height	27.2500	
Bottom Sash Width	25.3750	
Bottom Sash Height	28.2500	
Top Glass Width	22.6875	
Top Glass Height	25.5625	
Bottom Glass Width	23.6875	
Bottom Glass Height	26.5625	
Screen Width	23.9375	
Screen Height	54.7500	
Top Sash Weight (Plus 5 lb)	21 lb	
Top Balance Size (C.F)	56BU	
Top Balance Size (Spiral)	23-8R	
Bottom Sash Weight	17 lb	
Bottom Balance Size (C.F)	9NAT	
Bottom Balance Size (Spiral)	27-7R	
Egress Opening Width	23.2180	
Egress Opening Height	22.0625	
Egress Opening Area (sq.ft.)	3.5570	

*

Handwritten note: } Total Glass

→

→

Mln. W: 11	Max W: 52	
Mln. H: 20	Max H: 84	Max UI: 132
Exact Size		
Width:	27.625	27.625
Height:	57.625	57.625
Extrusion:	Select Extrusion	<< For Arch-Top Models Only
Opening:	Exact Size	
Type:	Standard	
Screen:	Full	
Glass:	Double Strength (3 mm)	

AC Sash Calculator

* $23.9 \times 54.7 \approx 1307 \div 144 = 9.0 \text{ sq ft}$