



**CITY OF SAINT PAUL**  
OFFICE OF THE CITY COUNCIL  
310 CITY HALL  
15 WEST KELLOGG BOULEVARD  
SAINT PAUL, MN 55102-1615  
EMAIL: [legislativehearings@ci.stpaul.mn.us](mailto:legislativehearings@ci.stpaul.mn.us)  
PHONE: (651) 266-8560 FAX: (651) 266-8574

March 15, 2011

Dan Schmidt  
RC Dept of Public Health  
2785 White Bear Ave N, Ste. 350  
Maplewood, MN 55109

Re: Appeal for property at 1081 Ross Avenue  
File ID #: ALH 11-356

Dear Mr. Schmidt:

This is to confirm that the Legislative Hearing Officer reviewed the above-referenced appeal and recommended granting a 2-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 22 inches high by 25 inches wide.

If you have any further questions, you may contact me at 651-266-8563.

Sincerely,

Mai Vang  
Legislative Hearing Coordinator

cc: Fire Supervisors (email)  
Pat Fish (email)  
Jim Bloom (email)  
Stephen Ubl (email)  
File