



APPLICATION FOR APPEAL

RECEIVED

APR 29 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- ☒ Copy of the City-issued orders or letter which are being appealed
- ☐ Attachments you may wish to include
- ☒ This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 5-17-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 2221 Edgumbe Rd City: St. PAUL State: MN Zip: 55116

Appellant/Applicant: Renewal by Andersen Email: bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): Annette & Kirby Hansen

Address (if not Appellant's): 2221 Edgumbe Rd St. PAUL MN 55116

Phone Numbers: Business _____ Residence 651-699-2231 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- ☐ Vacate Order/Condemnation/
- ☐ Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☐ Fire C of O Deficiency List
- ☒ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other
- ☐ Other
- ☐ Other

We are appealing the replacement of 3 windows that will not comply w/ Egress Policy. Current dimensions allow for 12 1/8" clear opening width. Clear opening height is exceeded by 10-22" for each window. Current windows are less than 5' sill to grade. EXCESS in operable height and overall glazed area for each window.
Please Approve.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: April 25, 2011

APPEAL PROPERTY ADDRESS: 2221 EDGCUMBE ROAD

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 11 133537

TYPE OF WINDOW Casement

NUMBER OF WINDOWS 1

Total Glazed Area Minimum 5 Square Feet	8.1 sq.ft.	Difference from Required Area	+ 3.1 sq.ft.
Width of Opening Minimum 20 Inches	12 1/8"	Difference from Required Opening	- 7 7/8"
Height of Opening Minimum 24 Inches	46 1/4"	Difference from Required Opening	+ 22 1/4"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	OK	Difference from Maximum Height	OK

COMMENTS: Decision to be determined by the legislative hearing officer

Reviewed by: jps

