


10/19/10
1:30



Saint Paul - Ramsey County Department of Public Health
Environmental Health Section
2785 White Bear Avenue North Suite 350
Maplewood, MN 55109-1320
FAX: (651) 266-1177

Date: 10/7/10

FACSIMILE TRANSMISSION

To FAX#: 6-8574

Cover Sheet and Transmittal Form

To: Mai Yang, Paralegal

Location: Legislative Hearing Office
City of St. Paul

Sender: Bruce Noyes / Tim Yannarelli
St. Paul - Ramsey Cty. Dept. of Public Health

This transmission consists of _____ pages (including cover sheet).

If transmission is incomplete or illegible, call sender at (651) 266-1142 (Bruce Noyes)

Message:

Request for Egress Window Non-Compliance Determination

Attachments: 1. Egress Window Non-Compliance Determination Form
2. Window Specifications - Exhibit A

CONFIDENTIALITY NOTICE

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 10/7/10

APPEAL PROPERTY ADDRESS: 750 SHERBURNE AVE #2, DOWNSTAIRS
ST. PAUL RAMSEY COUNTY

APPLICANT NAME: DEPT. OF PUBLIC HEALTH PHONE NUMBER: 651-266-1142 (Bruce)

BUILDING OWNER: HRA and Greater Frogtown CDC, Becky Errigo, 651-789-7484

PERMIT NUMBER: _____

TYPE OF WINDOW: DH

NUMBER OF WINDOWS: 1

TOTAL GLAZED AREA: 11.1 sq. ft

DIFFERENCE FROM REQUIRED AREA: Complies

WIDTH OF OPENING: 31.1 inches

DIFFERENCE FROM REQUIRED OPENING: Complies

HEIGHT OF OPENING: 19.8 inches

DIFFERENCE FROM REQUIRED OPENING: 4.2 inches

HEIGHT OF OPENING TO FINISHED FLOOR: Less than 48"

DIFFERENCE FROM MAXIMUM HEIGHT: Complies

RECOMMENDATION (IF APPLICABLE): _____

FROM: _____

Exhibit A.

Select a Model

(Model 0201)	
Excallbur Double Hung	
Top Sash Width	32.2600
Top Sash Height	24.8375
Bottom Sash Width	33.2600
Bottom Sash Height	25.8375
Top Glass Width	30.5525
Top Glass Height	23.2500
Bottom Glass Width	31.6625
Bottom Glass Height	24.2500
Screen Width	31.8125
Screen Height	50.1250
Top Sash Weight (Plus 5 lb)	24 lb
Top Balance Size (C.F)	66YW
Top Balance Size (Spiral)	21-9B
Bottom Sash Weight	21 lb
Bottom Balance Size (C.F)	56BU
Bottom Balance Size (Spiral)	25-6R
Egress Opening Width	31.0840
Egress Opening Height	19.7600
Egress Opening Area (sq.ft.)	4.2650

* } Total Glazed Area

Min. W: 12	Max. W: 53
Min. H: 20	Max. H: 60
Max. LT: 102	

	Exact Size
Width:	35.5
Height:	53

Extrusion: Select Extrusion << For Arch-Top Models Only

Opening: Exact Size

Type: Standard

Screen: Full

Glass: Double Strength (3 mm)

AC Sash Calculator

* $31.8 \times 50.1 = 1593.2 \div 144 = 11.07$