



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

February 17, 2011

Susan Gilmer
obo Cory & Susan Gilmer
1482 Sargent Ave
St. Paul, MN 55105

VIA EMAIL: susan.gilmer@yahoo.com

Re: Appeal for property at 443 and 447 Fairview Avenue South
File ID: ALH 11-246

Dear Mr. Gilmer:

This is to confirm that on February 15, 2011, at the Property Code Hearing, the Legislative Hearing Officer, recommended granting a 5-inch variance on the egress windows in 447 west and east bedrooms. The inspector will verify measurements of these egress windows on February 23, 2011 at 10:00 a.m. As for 443 east and west bedrooms, she recommended granting a 4.5-inch variance on the openable height of the egress windows.

If you have further questions, please contact me at 651-266-8563.

Sincerely,

/s/

Mai Vang
Legislative Hearing Coordinator

c: Fire Supervisors (email)
Pat Fish (email)
File

