



APPLICATION FOR APPEAL

Saint Paul City Clerk
15 W. Kellogg Blvd., 310 City Hall
Saint Paul, Minnesota 55102
Telephone: (651) 266-8688

OCT 07 2010

CITY CLERK

1. Address of Property being Appealed: <u>1431 Hartford Ave</u>	2. Number of Dwelling Units: <u>Single Family Dwelling</u>	3. Date of Letter Appealed: <u>10-5-10</u>
--	---	---

4. Name of Owner: Holly Gainer
 Address: 1431 Hartford City: St. Paul State: MN Zip: 55116
 Phone Numbers: Business _____ Residence 651-330-4038 Cellular _____
 Signature: _____

5. Appellant / Applicant (if other than owner): Renewal by Andersen
 Address: 1920 W GY Rd C City: Roseville State: MN Zip: 55113
 Phone Numbers: Business 651-264-4088 Residence _____ Cellular _____
 Signature: Bryan Horton

6 State specifically what is being appealed and why (Use an attachment if necessary):

We are appealing 3 replacement double hung windows that will not comply w/ Egress Policy. Opening width, opening height measurements included. All windows being replaced in 1 bedroom. Homeowner does want to keep existing look consistent w/ Replacements. Please Approve

NOTE: A \$25.00 filing fee made payable to the City of Saint Paul must accompany this application as a necessary condition for filing. You must attach a copy of the original orders and any other correspondence relative to this appeal. Any person unsatisfied by the final decision of the City Council may obtain judicial review by timely filing of an action as provided by law in District Court.

For Office Use Only

Date Received: <u>10/7/10</u>	Fee Received: <u>25</u>	Receipt Number:	Date of Hearing: <u>10/19/10</u> <u>Room 330 City Hall</u>
----------------------------------	----------------------------	-----------------	--

Revised 4/25/2007

Reviewed by: Rehn

COMMENTS: With the information provided above approval is recommended. 10-5-10 r

		36	Height of Opening to Finished Floor
OK	Difference from Maximum Height		
		18"	Height of Opening
	Difference from Required Opening		
		24"	Width of Opening
	Difference from Required Opening		
		8.8 sqft	Total Glazed Area
	Difference from Required Area		
		+3.8 sqft	

NUMBER OF WINDOWS 3

TYPE OF WINDOW Double hung

PERMIT NUMBER: 10 906144

PHONE NUMBER: 651-266-9071

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

APPEAL PROPERTY ADDRESS: 1431 HARTFORD AVE

DATE: October 5, 2010

SAINT PAUL, MN 55102

310 CITY HALL

15 KELLOGG BLVD. WEST

TO: CITY CLERK

PHONE: 651-266-8688
FAX: 651-266-8574

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

