

□ Other

APPLICATION FOR APPEAL

NOV 0 1 2010

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8560

\$25 filing fee payable to the City of S (if cash: receipt number) Copy of the City-issued orders or let are being appealed Attachments you may wish to include This appeal form completed	Saint Paul ter which	YOUR HEARING Date and Time: Tuesday, NOU-9 Time
Address Being Appeal	ed:	
		T. PAUL State: 1/11/2 Zip: 55106
Appellant/Applicant: JOHN	+ANSEN En	nail
		Cell <u>651-338-8418</u> Date: <u>10 -27 - 10</u>
Name of Owner (if other than Appellant):		<u> </u>
Address (if not Appellant's):		
Phone Numbers: Business	Residence	Cell
What Is Being appeale	d and why?	Attachments Are Acceptable
□ Vacate Order/Condemnation/ Revocation of Fire C of O □ Summary/Vehicle Abatement		
☐ Fire C of O Deficiency List ☐ Fire C of O: Only Egress Windows		
□ Code Enforcement Correction Notice	CODE 15	20" wide - 17" IS width
□ Vacant Building Registration		
□ Other		
□ Other		



CITY OF SAINT PAUL Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989 Facsimile: 651-266-8951

Web: www.stpaul.gov/dsi

4 phet was Built IN 1970 it HAS SAME WINDOWS

October 4, 2010

JUDITH HANSEN JOHN D HANSEN 1466 COUNTY ROAD H2 WHITE BEAR LAKE MN 55110

RE: RE-INSPECTION FIRE CERTIFICATE OF OCCUPANCY WITH DEFICIENCIES 386 KENNARD ST

Ref. # 99974

Dear Property Representative:

Your building was re-inspected for the Fire Certificate of Occupancy on October 4, 2010. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected immediately. A reinspection will be made on October 27. 2010 at 9:30 A.M..

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

DEFICIENCY LIST

- 386 Bottom MSFC1026.1 Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-Measured at 17inches openable width and 36inches openable height Sill 51 inches Glazed 34 inches height and 19 inches width. These are roll out windows with scissor brackets.
- 2. 386 Bottom - SPLC 34.13 (4) - Provide and maintain a minimum egress window sill height of 48 inches. Refer to provide handout EW-1 for more information.
- 3. 386 Upper - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)-

An Equal-Opportunity Employer