



APPLICATION FOR APPEAL

RECEIVED

MAY 02 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____)
- ☒ Copy of the City-issued orders or letter which
are being appealed
- ☐ Attachments you may wish to include
- ☒ This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 5-17-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

walk-in

Address Being Appealed:

Number & Street: 1537 St Clair Ave City: St Paul State: MN Zip: 55105

Appellant/Applicant: Steven Davis Email _____

Phone Numbers: Business 651 646 1125 Residence 651 554 8069 Cell _____

Signature: [Signature] Date: 4/26/11

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- ☐ Vacate Order/Condemnation/
- ☐ Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☐ Fire C of O Deficiency List
- ☒ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other
- ☐ Other
- ☐ Other

1 window



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

April 4, 2011

STEVEN B DAVIS
1576 BOARDWALK CT
MENDOTA HEIGHTS MN 55118-2747

FIRE INSPECTION CORRECTION NOTICE

RE: 1537 ST CLAIR AVE
Ref. #102990
Residential Class: C

Dear Property Representative:

Your building was inspected on April 4, 2011 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

A re-inspection will be made on May 6, 2011 at 1:00 PM.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. 2nd Floor - Bedroom - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.
-Double hung egress window measured 20.5 inches height by 26.5 inches width openable space and has a glazed area of 8.2 square feet.

2. 2nd Floor - MN State Statute 299F.50 Immediately provide and maintain an approved Carbon Monoxide Alarm in a location within ten (10) feet of each sleeping area. Installation shall be in accordance with manufacturers instructions.
3. Basement - MSFC 605.1 - Repair or replace damaged electrical fixtures. This work may require a permit(s). Call DSI at (651) 266-9090. -Repair outlet with reversed polarity.
4. Basement - MSFC 3404.3.4, SPLC 34.15 (1) - Reduce and maintain the flammable or combustible liquids storage quantity in accordance with MSFC 2703.1.1(1) or other approved storage methods. -Remove gas can from building.
5. Basement - SPLC 34.11 (4), 34.34 (1), MPC 4515, MPC 326 - Connect or cap the sewer piping in accordance with the plumbing code. This work will require a permit. Contact DSI at 651-266-8989. -Contact a licensed plumber to install laundry sink drain to code.
6. Bathroom - SPLC 34.14 (3), MPC 4715.200.T - Provide and maintain a window or approved ventilation system in all bathrooms.
7. Exterior - Rear - SPLC 71.01 - The address posted is not visible from street. (HN-1) -Provide reflective numbers or background or illuminate at night.
8. Interior - MSFC 605.4 - Discontinue use of all multi-plug adapters. -1st floor and 2nd floor.
9. Interior - SPLC 34.09 (3), 34.32 (3) - Repair and maintain the window locks. -Where needed throughout.
10. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
11. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.

For an explanation or information on some of the violations contained in this report, please visit our web page at: <http://www.ci.stpaul.mn.us/index.aspx?NID=211>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: william.beumer@ci.stpaul.mn.us or call me at 651-266-8991 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

William Beumer
Fire Inspector

www.stpaul.gov rjn App 15 May