



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street., Suite 220
Saint Paul, MN 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-1919
Web: www.stpaul.gov/dsi

355

February 19, 2013

12-053944

US Bank National Assoc ND
205 W 4th St #500
Cincinnati OH 45202-4812

Tom Herzog Real Estate
5120 Edina Industrial Blvd
Edina MN 55439

Kenneth Johnson
Johnson Blumberg & Associates
230 W Monroe Street #1125
Chicago IL 60606

Order to Abate Nuisance Building(s)

Dear Sir or Madam:

The Vacant/Nuisance Buildings Unit, Department of the Department of Safety and Inspections, Division of Code Enforcement, hereby declares the premises located at:

745 HAWTHORNE AVE E

With the following Historic Preservation information: NONE

District: Building Name: house Inventory #: RA-SPC-1733

and legally described as follows, to wit:

Oak Ville Park W 1o Ft Of Lot 13 And All Of Lot 12 Blk 8

to comprise a nuisance condition in violation of the Saint Paul Legislative Code, Chapter 45.02, and subject to demolition under authority of Chapter 45.11.

On February 13, 2013 a Building Deficiency Inspection Report was compiled and the following conditions were observed.

This list of deficiencies is not necessarily all the deficiencies present at this time. This building(s) is subject to the restrictions of Saint Paul Ordinance Chapter 33.03 and shall not again be used for occupancy until such time as a Certificate of Compliance or a Certificate of Occupancy has been issued. All repairs must be in accordance with appropriate codes. Changes or additions to the electrical system, mechanical system, or the plumbing system may necessitate updating or upgrading the systems involved.

This is a one and one-half story, wood frame, single-family dwelling.

The following Deficiency List is excerpted from the February 1, 2013 Code Compliance Report.

BUILDING

- Remove or encapsulate asbestos in an approved manner.
- Install handrails (34 inches - 38 inches above each nosing) and guardrails (36 inch minimum) at all stairways, and return hand rail ends into a newel post or wall per attachment.
- Repair or Replace any deteriorated window sash, broken glass, sash holders, re-putty, etc as necessary.
- Provide complete storms and screens, in good repair for all door and window openings.
- Repair or replace damaged doors and frames as necessary, including storm doors.
- Repair walls, ceiling and floors throughout, as necessary.
- Prepare and paint interior and exterior as necessary. Observe necessary abatement procedures (EPA, MPCA and St. Paul Legislative Code, Chapter 34 for additional information) if lead base paint is present.
- Any framing members that required repair or do not meet code (where wall and ceiling covering is removed, members that are over-spanned, over-spaced, not being carried properly, door and window openings that are not adequately supported, etc.) are to be reconstructed in an approved manner.
- Provide fire block construction as necessary and seal chases in basement ceiling.
- Air-seal and insulate attic/access door.
- Install Smoke Detectors/Carbon Monoxide Detectors per MN Conservation Code and the MN Dept. of Labor and Industry: Install per code where feasible.
- Provide major clean-up of premises.
- Repair siding, soffit, fascia, trim, etc. as necessary.
- Provide proper drainage around house to direct water away from foundation of house.
- Replace house roof covering and vents to code.
- Provide durable, dustless parking surface as specified in the zoning code.
- Openings in stair risers must be less than 4 inches.
- Install steps at west front entry.
- Install drip cap on doors and windows where missing.
- Install new roof covering on house.
- Re-level southwest porch and repair roof framing when replacing roof covering.
- Properly repair floor joist and anchor beams in basement.
- A building permit is required to correct the above deficiencies.

ELECTRICAL

- Bond around water meter with a copper wire sized for the electrical service per Article 250 of the NEC
- Provide a complete circuit directory at service panel indicating location and use of all circuits
- Verify/install a separate 20 ampere laundry circuit and a separate 20 ampere kitchen appliance circuit
- Install S type fuse adapters and proper size S fuses listed circuit breakers

- Close openings in service panel/junction boxes with knockout seals, breaker blanks, and/or junction box covers
- Properly strap cables and conduits in basement/ service conduit on the exterior of the house.
- Repair or Replace all broken, missing or loose light fixtures, switches and outlets, covers and plates
- Check all outlets for proper polarity and verify ground on 3-prong outlets
- Install hard-wired, battery backup smoke detector and other smoke detectors as required by the IRC. Also, Install carbon monoxide detector(s) within 10 feet of all bedrooms
- Replace all painted-over receptacles.
- Add receptacle in first floor living room per SPLC 34.14(2)b.
- Add receptacle in second floor middle bedroom per SPLC 34.14(2)b.
- Remove/rewire hood fan in kitchen to 2011 NEC.
- Disconnect or GFCI protect receptacle on kitchen sink light.
- Install box extensions on devices mounted in wood paneling per NEC.
- Remove service knob from window sill and relocate per NEC.
- Based on repair list purchase permit for 8 circuits.
- All added receptacles must be grounded, tamper-resistant and be on an Arc-Fault Circuit Interrupter-protected circuit.
- Any open walls or walls that are opened as part of this project must be wired to the standards of the current NEC.
- All electrical work must be done by a Minnesota-licensed electrical contractor under an electrical permit.

PLUMBING

- Basement - Water Heater - No gas shut off or gas piping incorrect (MFGC 402.1)
- Basement - Water Heater - T and P relief discharge piping incorrect (MPC 2210 Subp. 4)
- Basement - Water Heater - gas venting incorrect (MFGC 503)
- Basement - Water Heater - not fired or in service (MPC 2180)
- Basement - Water Meter - corroded piping; incorrect piping (MPC 0200 0.)
- Basement - Water Meter - meter needs repair or is broken (SPRW Sec. 88.10)
- Basement - Water Meter - service valves not functional or correct (MPC 1800 Subp 3,4)
- Basement - Water Piping - improper fittings or usage (MPC 0420)
- Basement - Water Piping - provide water piping to all fixtures and appliances (MPC 1700)
- Basement - Water Piping - repair or replace all corroded, broken or leaking piping (MPC 4715.1720)
- Basement - Water Piping - run 1 inch water line from meter to first major take off (SPRWS Water Code)
- Basement - Laundry Tub - faucet is missing, broken or parts missing (MPC 0200. P.)
- Basement - Laundry Tub - unvented (MPC 0200 E)
- Basement - Laundry Tub - waste incorrect (MPC 2300)
- First Floor - Gas Piping - range gas shut off; connector or piping incorrect (MFGC 411)
- First Floor - Sink - waste incorrect (MPC 2300)
- Second Floor - Lavatory - waste incorrect (MPC 2300)

- Second Floor - Tub and Shower - Provide a vacuum breaker for the handheld shower (MPC 2000 B)
- Second Floor - Tub and Shower - replace waste and overflow (MPC 1240)
- All the above corrections to waste, vent, water, and gas piping shall be per the Minnesota Plumbing Code Chapter 4715 & Chapter 326, the Minnesota Mechanical Code, the Minnesota Fuel Gas Code, and the Saint Paul Regional Water Code. All plumbing must be done by a plumbing contractor licensed in the State of Minnesota and the City of St. Paul under an approved permit.

HEATING

- Clean and Orsat test furnace burner. Check all controls for proper operation. Check furnace heat exchanger for leak; provide documentation from a licensed contractor that the heating unit is safe
- Support furnace flue venting to code.
- Vent clothes dryer to code.
- Provide adequate combustion air and support duct to code
- Provide support for gas lines to code
- Plug, cap and/or remove all disconnected gas lines
- Provide a window in the bathrooms with an aggregate glazing area of not less than 3 square feet, one-half of which must be openable or provide exhaust system vented to outside. A mechanical ventilation permit is required if an exhaust system is installed.
- All supply and return ducts for warm air heating system must be clean before final approval for occupancy. Provide documentation from a licensed duct-cleaning contractor that the duct system has been cleaned.
- Repair and/or replace heating registers as necessary
- Provide heat in every habitable room and bathrooms
- Provide a means of returning air from every habitable room to the furnace. Return air can not be taken from closets, bathrooms, toilet rooms, kitchen or mechanical rooms.
- Remove or abate any friable asbestos material. Provide documentation that any abatement was performed by a state licensed asbestos abatement contractor.
- Mechanical gas and ventilation permits are required for the above work.

As owner, agent or responsible party, you are hereby notified that if these deficiencies and the resulting nuisance condition is not corrected by **March 21, 2013** the Department of Safety and Inspections, Division of Code Enforcement, will begin a substantial abatement process to demolish and remove the building(s). The costs of this action, including administrative costs and demolition costs will be assessed against the property taxes as a special assessment in accordance with law.

As first remedial action, a Code Compliance Inspection Report must be obtained from the Building Inspection and Design Section, 375 Jackson Street, Suite 220, (651) 266-8989. This inspection will identify specific defects, necessary repairs and legal requirements to correct this nuisance condition. You may also be required to post a five thousand dollar (\$5,000.00) performance bond with the Department of Safety and Inspections before any permits are issued, except for a demolition permit. Call the Department of Safety and Inspections for more information at 651-266-8989.

If this building is located in a historic district or site (noted on page 1, above, just below the property address) then you must contact Heritage Preservation (HPC) staff to discuss your proposal for the repairs required by this order and compliance with preservation guidelines. Copies of the guidelines and design review application and forms are available from the Department of Safety and Inspections web site (see letterhead) and from the HPC staff. No permits will be issued without HPC review and approval. HPC staff also can be reached by calling 651-266-9078.

As an owner or responsible party, you are required by law to provide full and complete disclosure of this "Order to Abate" to all interested parties, all present or subsequent renters and any subsequent owners. The property shall not be sold, transferred or conveyed in any manner until the Nuisance Conditions have been abated and the Certificate of Code Compliance or Certificate of Occupancy has been issued.

The Enforcement Officer is required by law to post a placard on this property which declares it to be a "nuisance condition", subject to demolition and removal by the City. This placard shall not be removed without the written authority of the Department of Safety and Inspections, Division of Code Enforcement. The department is further required to file a copy of this "Order to Abate" with the City Clerk's Office.

If corrective action is not taken within the time specified in this order, the Enforcement Officer will notify the City Council that abatement action is necessary. The City Clerk will then schedule dates for Public Hearings before the City Council at which time testimony will be heard from interested parties. After this hearing the City Council will adopt a resolution stating what action if any, it deems appropriate.

If the resolution calls for abatement action the Council may either order the City to take the abatement action or fix a time within which this nuisance must be abated in accordance with the provisions of Chapter 33 of the Saint Paul Legislative Code and provide that if corrective action is not taken within the specified time, the City shall abate this nuisance. The costs of this action, including administrative costs will be assessed against the property as a special assessment in accordance with law.

If you have any questions or request additional information please contact **Tom Friel** between the hours of 8:00 and 9:30 a.m. at **651-266-1906**, or you may leave a voice mail message.

Sincerely,

Tom Friel
Vacant Buildings Enforcement Inspector

cc: Legistar Approval list and City Council