

8-23-11 @ 1:30

RECEIVED
AUG 03 2011
CITY CLERK

Saint Paul - Ramsey County Department of Public Health
Environmental Health Section
2785 White Bear Avenue North Suite 350
Maplewood, MN 55109-1320
FAX: (651) 266-1177

Date: _____

To/FAX#: 6-8574

FACSIMILE TRANSMISSION
Cover Sheet and Transmittal Form

To:	Mai Yang Paralegal
Location:	Legislative Hearing Office City of St. Paul
Sender:	Daniel Schmidt / Jim Yannarelli St. Paul - Ramsey Cty. Dept. of Public Health

This transmission consists of _____ pages (including cover sheet).

If transmission is incomplete or illegible, call sender at (651) 266-1143 (DANIEL SCHMIDT)

Message:

Request for Egress Window Non-Compliance Determination
Attachments: Egress Window Non-Compliance Determination Form

CONFIDENTIALITY NOTICE

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8686
FAX: 651-266-8574

DATE: 8-3-11

APPEAL PROPERTY ADDRESS: 1008 Pacific
APPLICANT NAME: PUBLIC HEALTH (DANIEL)
ON BEHALF OF MIKE SUTHERO (SUTHERO)

PHONE NUMBER: 651-266-1143

PERMIT NUMBER: _____

TYPE OF WINDOW: DK

NUMBER OF WINDOWS: 2

TOTAL GLAZED AREA: 9.0 sq ft DIFFERENCE FROM REQUIRED AREA: COMPLIES

WIDTH OF OPENING: 25" DIFFERENCE FROM REQUIRED OPENING: COMPLIES

HEIGHT OF OPENING: 20" DIFFERENCE FROM REQUIRED OPENING: 4"

HEIGHT OF OPENING TO FINISHED FLOOR: 48" DIFFERENCE FROM MAXIMUM HEIGHT: COMPLIES

RECOMMENDATION (IF APPLICABLE): SEE ATTACHED

FROM: _____

Select a Model
0201
(Model 0201)
Extra Ibur Double Hung

Min. W: 11	Max. W: 32	Min. H: 20	Max. H: 34	Max. UJ: 132
Width: 25.5	Height: 53.5	Unit Size: 23.5	Unit Size: 63.5	

Emulsion: Select Emulsion
 Operating: Exact Size
 Type: Standard
 Screen: Full
 Glass: Double Strength (2 mm)

AC Sash Channels

Top Sash Width	24.2500
Top Sash Height	24.4575
Bottom Sash Width	21.2500
Bottom Sash Height	26.1875
Top Glass Width	24.5825
Top Glass Height	23.5000
Bottom Glass Width	23.5825
Bottom Glass Height	24.5000
Screen Width	24.8125
Screen Height	50.4350
Top Sash Weight (Plus S B)	21.45
Top Balance Size (C-F)	58BU
Top Balance Size (Spiral)	21-7B
Bottom Sash Weight	17.1b
Bottom Balance Size (C-F)	SNAT
Bottom Balance Size (Spiral)	2S-8R
Egress Draining Width	25.0940
Egress Operating Height	20.0060
Egress Opening Area (sq. ft.)	3.4893

TOTAL GUARDED AREA

* $25.8 \times 50.6 = 1305 \div 144 = 9.0 \text{ sq ft}$