



✓ Scanned

# APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

RECEIVED

JUL 01 2011

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number pd)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR  Mail-In

**YOUR HEARING Date and Time:**  
 Tuesday, 7-5-11  
 Time 1:30  
 Location of Hearing:  
 Room 330 City Hall/Courthouse  
 walk-in

## Address Being Appealed:

Number & Street: 1569 REANEY AVE City: ST PAUL State: MN Zip: 55106

Appellant/Applicant: CHAMPION WINDOWS OF MPLS. Email: MINNEAPOLIS. RWMGR @ CHAMPIONFACTORYDIRECT.COM

Phone Numbers: Business 763-574-2054 Residence \_\_\_\_\_ Cell 763-226-1356

Signature: Ron Anlusser Date: July 1, 2011

Name of Owner (if other than Appellant): SIMON THAO

Address (if not Appellant's): 1569 REANEY AVE. ST. PAUL, MN 55106

Phone Numbers: Business \_\_\_\_\_ Residence 651-774-5344 Cell \_\_\_\_\_

## What Is Being Appealed and Why?

Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

## EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: June 30, 2011

APPEAL PROPERTY ADDRESS: 1569 REANEY AVE

APPLICANT NAME: CHAMPION WINDOW COMPANY OF MINNEAPOLS  
LLC

PHONE NUMBER: 763-574-2054

PERMIT NUMBER: 11 141271

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS

<b>Total Glazed Area</b> Minimum 5 Square Feet	7.1	<b>Difference from Required Area</b>	+2.1
<b>Width of Opening</b> Minimum 20 Inches	34.5	<b>Difference from Required Opening</b>	+14.5
<b>Height of Opening</b> Minimum 24 Inches	16.85	<b>Difference from Required Opening</b>	-7.15
<b>Height of Opening to Finished Floor</b> Maximum 48 Inches for Existing Openings	44	<b>Difference from Maximum Height</b>	+4

COMMENTS: revised window height opening per information provided by Ron Anderson at Champion.

Reviewed by: dd 6-30-11