



APPLICATION FOR APPEAL

Saint Paul City Clerk

RECEIVED

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

APR 19 2012

CITY CLERK

The City Clerk needs the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____)
- ☒ Copy of the City-issued orders or letter which
are being appealed
- ☐ Attachments you may wish to include
- ☐ This appeal form completed
- ☐ Walk-In OR ☒ Mail-In

YOUR HEARING Date and Time:

Tuesday, 4-24-12

Time 11:00am

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 649 Western City: St. Paul State: Mn Zip: 55103

Appellant/Applicant: Gary Nelson Email: gnelsonhomes@yahoo.com

Phone Numbers: Business 651-983-6789 Residence _____ Cell 651-983-6789

Signature: Gary Nelson Date: 4/17/12

Name of Owner (if other than Appellant): Mary Brinker / Sheila Brinker

Address (if not Appellant's): 1145 Hudson Rd #313

Phone Numbers: Business _____ Residence 330-2188
489-4903 Cell 308-1969

What Is Being Appealed and Why? *Attachments Are Acceptable*

- ☒ Vacate Order/Condemnation/
Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☒ Fire C of O Deficiency List
- ☐ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other

We want a time extension
to finish repairs
some of the repairs are
being done through an
insurance claim



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

April 13, 2012

SHEILA M BRINKER
Mary E Brinker
1145 HUDSON ROAD #313
ST PAUL MN 55106

Revocation of Fire Certificate of Occupancy and Order to Vacate

RE: 649 WESTERN AVE N

Dear Property Representative:

Your building was inspected on April 6, 2012, for the renewal of the Certificate of Occupancy. Since you have failed to comply with the applicable requirements, it has become necessary to revoke the Certificate of Occupancy in accordance with Section 40.06 of the Saint Paul Legislative Code.

A re-inspection will be made on May 1, 2012 or the property vacated.

The Saint Paul Legislative Code further provides that no building shall be occupied without a Certificate of Occupancy. Failure to immediately complete the following deficiency list or the building vacated may result in a criminal citation.

DEFICIENCY LIST

1. Exterior - SPLC 34.09 (1) b,c, 34.32 (1) b,c - Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint.
2. Exterior - SPLC 34.09 (1) a, 34.32 (1) a - Provide and maintain foundation elements to adequately support this building at all points.
3. Exterior-Front Steps - SPLC 34.09 (2), 34.32(2) - Repair or replace the damaged guardrail in an approved manner. This work requires a permit(s). Call DSI at (651) 266-9090.
4. Exterior-Front Steps - SPLC 34.09 (2) 34.32 (2) - Provide an approved handrail. The top of the handrail must be between 34 and 38 inches above the treads and run the entire length of the stair.
5. Exterior-Throughout - SPLC 34.09 (3), 34.32 (3) - Repair and maintain the window glass.
6. Exterior-Throughout - SPLC 34.09 (3), 34.32 (3) - Provide or repair and maintain the window screens.

7. Exterior-Throughout - SPLC 34.08 (5), 34.31 (3) - Repair, replace and maintain all exterior surfaces on fences, sheds, garages and other accessory structures free from holes and deterioration. Provide and maintain exterior unprotected surfaces painted or protected from the elements.
8. Exterior-Throughout - SPLC 34.09 (2), 34.32(2) - Repair or replace the unsafe stairways, porch, decks or railings in an approved manner. This work may require a permit(s). Call DSI at (651) 266-9090.
9. Interior- Unit 1 - SPLC 34.23, MSFC 110.1 - This occupancy is condemned as unfit for human habitation. This occupancy must not be used until re-inspected and approved by this office.- Condemned due to cracked furnace.
10. Interior-Basement - SPLC 34.10 (3) 34.33(2) - Provide an approved guardrail. Intermediate ballustrade must not be more than 4 inches apart. Intermediate rails must be provided if the height of the platform is more than 30 inches.
11. Interior-Basement - SPLC 34.10 (3), 34.33(2) - Provide an approved handrail. The top of the handrail must be between 34 and 38 inches above the treads and run the entire length of the stair.
12. Interior-Basement - UMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work may require a permit(s). Call DSI at (651) 266-8989.-Hire a licensed contractor to install the dryer vent to meet code. Remove screws and duct tape.
13. Interior-Closets throughout - MSFC 605.1- All light fixtures shall be maintained with protective globes if originally equipped.-All closets must have globe covers on the light fixtures.
14. Interior-Front Entry- Unit 2 - MSFC 605.1 - Repair or replace damaged electrical fixtures. This work may require a permit(s). Call DSI at (651) 266-9090.-Repair or replace loose light fixture in the entry to unit 2.
15. Interior-Rear Entry/Exit Unit 2 - SPLC 34.10 (7), 34.33 (6) - Repair and maintain the floor in an approved manner.-Repair or replace the floor tile in the rear entry of unit 2.
16. Interior-Rear steps from Unit 2. - SPLC 34.10 (3), 34.33(2) - Repair or replace the unsafe stairway in an approved manner.-Repair or replace all broken steps to the exit in the back of unit 2.
17. Interior-Throughout - SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.-Report received from Inspections Plus stating the gas controls defective, and the furnace is cracked. Immediately discontinue use until replaced under permit.
18. Interior-Throughout - SPLC 34.19 - Provide access to the inspector to all areas of the building.
19. Interior-Throughout - SPLC 34.08 (10) - Repair, replace and maintain exterior sidewalks, walkways and stairs.-Repair the damaged cement stairs at the rear of the building.
20. Interior-Throughout - SPLC 34.10 (7), 34.33 (6) - Repair and maintain the ceiling in an approved manner.-Patch and paint the holes and/or cracks in the ceilings throughout.

21. Interior-Throughout - SPLC 34.10 (7), 34.33 (6) - Repair and maintain the walls in an approved manner.-Patch and paint the holes and/or cracks in the walls throughout.
22. Interior-Throughout - SPLC 34.09 (3) i - Provide and maintain an approved one-inch throw single cylinder deadbolt lock.-Remove unapproved double keyed deadbolts and all slide bolt locks from exit doors.
23. Interior-Throughout - SPLC 34.11 (6) - Provide and maintain a minimum of 68 degrees F in all habitable rooms at all times.
24. Interior-Throughout - MN Rules 1300.0180 - Immediately discontinue use of unsafe heating appliance until repaired or replaced by a licensed contractor. This work may require a permit(s). Call DSI at (651) 266-9090. Red tags may not be removed except by fire department inspector.- Repair or replace the cracked furnace under permit.
25. SPLC 39.02(c) - Complete and sign the provided smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: lisa.martin@ci.stpaul.mn.us or call me at 651-266-8988 between 6:30 - 8:30 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Lisa Martin
Fire Inspector