



APPLICATION FOR APPEAL

RECEIVED
DEC 10 2010
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number N/A)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, Dec. 21 2010

Time 1:30 p.m.

Location of Hearing:

Room 330 City Hall/Courthouse

walk-in, Rec'd cc of form.

Address Being Appealed:

Number & Street: 2044 LaCrosse City: St. Paul State: MN Zip: 55104

Appellant/Applicant: William Flowers Email: flow0033@yahoo.com

Phone Numbers: Business 651-485-5960 Residence _____ Cell _____

Signature: *William Flowers* Date: 12-10-10

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): 937 Marshall Ave St. Paul MN 55104

Phone Numbers: Business 651-485-5960 Residence _____ Cell _____

What Is Being appealed and why?

Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

Inspector Thomas was concern with the windows "openable" space windows measure at least 24 in wide.



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

November 3, 2010

WILLIAM FLOWERS
937 MARSHALL AVE
ST PAUL MN 55104-6549

RECEIVED
DEC 10 2010
CITY CLERK

FIRE INSPECTION CORRECTION NOTICE

RE: 2044 LACROSSE AVE
Ref. #110923
Residential Class: C

Dear Property Representative:

Your building was inspected on November 3, 2010 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. A re-inspection will be made on November 23, 2010 at 1:45 P.M.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. Bathrooms - SPLC 34.10 (4), 34.33 (3) - Provide a bathroom floor impervious to water. After securing toilets to floor caulk the base of the toilets.
2. Bathrooms - SPLC 34.11, SBC 2902.1, SPLC 34.17, MPC 415.0220 - Repair or replace and maintain the plumbing fixture to an operational condition.-Repair or replace and maintain an approved private toilet. This work may require a permit(s). Call LIEP at (651) 266-9090. Secure upstairs and downstairs toilets to floor.
3. Bedroom South East Side - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. Refer to provide handout EW-1 for more information.-Bedroom has awning windows with 35inches openable width 8inches openable height sill 43inches

4. Bedroom East Side - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. Refer to provide handout EW-1 for more information.-Windows measure at 20inches openable height 27inches openable width glazed 40inches sill 23
5. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
6. SPLC 39.02(c) - Complete and sign the provided smoke detector affidavit and return it to this office.
7. MSFC 605.5 - Discontinue use of extension cords used in lieu of permanent wiring.-Various locations
8. UMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. The entire exhaust system shall be supported and secured in place. Installation requires a permit. At time of inspection exhaust was made of plastic.
9. MN State Statute 299F.50 Immediately provide and maintain an approved Carbon Monoxide Alarm in a location within ten (10) feet of each sleeping area. Installation shall be in accordance with manufacturers instructions.

For an explanation or information on some of the violations contained in this report, please visit our web page at: <http://www.ci.stpaul.mn.us/index.aspx?NID=211>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: james.thomas@ci.stpaul.mn.us or call me at 651-266-8983 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas
Fire Inspector

Reference Number 110923