



**CITY OF SAINT PAUL**  
OFFICE OF THE CITY COUNCIL  
310 CITY HALL  
15 WEST KELLOGG BOULEVARD  
SAINT PAUL, MN 55102-1615  
EMAIL: [legislativehearings@ci.stpaul.mn.us](mailto:legislativehearings@ci.stpaul.mn.us)  
PHONE: (651) 266-8560 FAX: (651) 266-8574

November 12, 2010

Xai Xiong  
7035 Stratford Echo  
Woodbury, MN 55125

Re: Appeal for property at 961-963 Wilson Avenue  
ALH 10-159

Dear Mr. Xiong:

This is to confirm that on November 5, 2010, Inspector Kelly Booker inspected the above-referenced property matter and stated that the double hung windows in Unit 2 of 963 south bedroom measured at 18.5 inches high by 35 inches wide. The north bedroom was measured at 20 inches high by 19 inches wide. Based on these dimensions, Marcia Moermond, Legislative Hearing Officer recommended granting a 5.5-inch on the openable height of the egress window in the south bedroom and a 5-inch variance on the openable height of the egress window in north bedroom.

If you have any questions, you may contact me at 651-266-8563.

Sincerely,

Mai Vang  
Hearing Coordinator

cc: Fire Supervisors  
Pat Fish  
File

