



**CITY OF SAINT PAUL**  
OFFICE OF THE CITY COUNCIL  
310 CITY HALL  
15 WEST KELLOGG BOULEVARD  
SAINT PAUL, MN 55102-1615  
EMAIL: [legislativehearings@ci.stpaul.mn.us](mailto:legislativehearings@ci.stpaul.mn.us)  
PHONE: (651) 266-8560 FAX: (651) 266-8574

April 29, 2011

Joe Palen  
2533 – 8<sup>th</sup> St  
White Bear Twnsp MN 55110

Re: Appeal for property at 1505 Old Hudson Road  
File ID: ALH 11-486

Dear Mr. Palen:

This is to confirm that on April 26, 2011 at the Property Code Hearing, Marcia Moermond, Legislative Hearing Officer recommended denying the appeal on the egress windows in the main floor southeast, northeast and northwest bedrooms and granting an extension for 90 days to come into compliance. You must also install a step full width (9-10" in length and 11" depth) below the egress bedroom windows to address the sill height issue.

If you wish to contest further, you may attend the City Council public hearing on Wednesday, May 18, 2011 at 5:30 p.m. in Room 300 Council Chambers.

If you have any questions, you may contact me at 651-266-8563.

Sincerely,

Mai Vang  
Legislative Hearing Coordinator

cc: Fire Supervisors (email)  
Pat Fish (email)  
File

