



CITY OF SAINT PAUL  
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220  
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989  
Facsimile: 651-266-8951  
Web: [www.stpaul.gov/dsi](http://www.stpaul.gov/dsi)

February 21, 2017

CHERYL MIKEL  
LOVE IN ACTION, LLC  
4550 HELMO PLACE N  
OAKDALE MN 55128 USA

## CORRECTION NOTICE - RE-INSPECTION COMPLAINT

RE: 605 COMO AVE –RAINBOW CHILD CARE CENTER  
Ref. # 36885

Dear Property Representative:

A re-inspection was made on your building on February 21, 2017, in response to a referral. You are hereby notified that the following deficiencies must be corrected immediately. A reinspection will be made on or after March 21, 2017.

Failure to comply may result in a criminal citation or the revocation of the Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

### DEFICIENCY LIST

1. THROUGHOUT BULIDING - PROVIDE REQUIRED FIRE ALARM SYSTEM - MSFC 1103.7 - Provide an approved fire alarm system. This work may require a permit(s). Call DSI at (651) 266-8989. **-For DHS Licensed Child Care Centers with a capacity of 50 children or more, an approved fire alarm system including detection and notification.** Initiation of the system shall be by manual and automatic means. Boiler and furnace rooms, mechanical and electrical rooms, shops, laboratories, kitchens locker rooms, janitor closets, trash-collection rooms, storage rooms, lounges and Approved automatic fire detectors shall be provided in the following: laundry rooms, similar areas. Activation of the fire alarm system shall initiate a general evacuation signal. All fire alarm systems must meet the requirements in NFPA 72 (2010 Edition) National Fire Alarm and Signaling Code.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

An Equal Opportunity Employer

If you have any questions, email me at [james.perucca@ci.stpaul.mn.us](mailto:james.perucca@ci.stpaul.mn.us) or call me at 651-266-8996 between 7:30 a.m. - 9:00 a.m.

Please help to make Saint Paul a safer city in which to live and work.

Sincerely,

James Perucca  
Fire Inspector

Ref. # 36885