



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

*375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806*

*Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi*

September 7, 2012

M & E Mckay Llc
8375 80th St N
Stillwater MN 55082-8399

Revocation of Fire Certificate of Occupancy and Order to Vacate

RE: 651 UNIVERSITY AVE W
Ref. # 15803

Dear Property Representative:

Your building was determined to be a registered vacant building on September 7, 2012. Since certificates are for the occupancy of buildings, it has become necessary to revoke the Certificate of Occupancy.

Saint Paul Legislative Code provides that no building shall be occupied without a Certificate of Occupancy. In order to re-occupy the building, the following deficiencies (if applicable) must be corrected and a complete Certificate of Occupancy inspection will be required.

DEFICIENCY LIST

1. EXTERIOR - WEST SIDE OF THE BUILDING - MSFC 605.1 - Repair or replace damaged electrical fixtures. This work may require a permit(s). Call DSI at (651) 266-9090.
2. THROUGHOUT - SPLC 33.05 - Uncertified portions of the building must not be occupied until inspected and approved by this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: Sebastian.Migdal@ci.stpaul.mn.us or call me at 651-266-8985 between 8:00 - 9:30 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Sebastian Migdal
Fire Inspector

Ref. # 15803