

## Moermond, Marcia (CI-StPaul)

---

**From:** Perucca, James (CI-StPaul)  
**Sent:** Thursday, February 20, 2020 2:01 PM  
**To:** Moermond, Marcia (CI-StPaul)  
**Cc:** Imbertson, Mitchell (CI-StPaul)  
**Subject:** 584 Fairview Ave N -Harcros Chemical Update

Good Afternoon Marcia,

I was out to Harcros Chemical this morning to review their reduction of Class IIIB liquids, property flammable liquid storage and separation of oxidizers from combustible material in the building. All appears to be in order and substances below maximum allowable quantities for this warehouse.

An updated emergency management plan is still in the process of review and will be sent to me no later than 02/28/2020. Request for proposals are out for the sprinkler installation. They are expecting to have bids submitted by 03/06/2020.

I will update you as information becomes available to me.

Sincerely,  
Jim

Jim Perucca, CFI  
Fire Safety Inspector III  
Commercial Inspection Supervisor  
City of Saint Paul  
Department of Safety and Inspections  
651-266-8996