



# APPLICATION FOR APPEAL

**Saint Paul City Clerk**

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

RECEIVED

JUN 04 2012

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number 90531)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR  Mail-In

YOUR HEARING Date and Time:

Tuesday, 6-19-12

Time 1:30 P.m.

Location of Hearing:

Room 330 City Hall/Courthouse

## Address Being Appealed:

Number & Street: 1412 Taylor City: ST Paul State: MN Zip: \_\_\_\_\_

Appellant/Applicant: Scott Spiess Email KQ SPIESS@MSN.COM

Phone Numbers: Business 651-248-3853 Residence 651-653-9453 Cell 651-248-3853

Signature: [Handwritten Signature] Date: \_\_\_\_\_

Name of Owner (if other than Appellant): \_\_\_\_\_

Address (if not Appellant's): \_\_\_\_\_

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell \_\_\_\_\_

## What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

Short by 4 inches with 27 inches wide 6.75 SQ FT TOTAL



CITY OF SAINT PAUL  
*Christopher B. Coleman, Mayor*

375 Jackson Street, Suite 220  
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989  
Facsimile: 651-266-8951  
Web: [www.stpaul.gov/dsi](http://www.stpaul.gov/dsi)

May 23, 2012

SCOTT B SPIESS  
493 Bear Ave S  
St Paul MN 55127-7018

### FIRE INSPECTION CORRECTION NOTICE

RE: 1412 TAYLOR AVE  
Ref. #109277  
Residential Class: B

Dear Property Representative:

Your building was inspected on May 22, 2012 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. **A re-inspection will be made on June 21, 2012 at 2:00 pm.**

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

**YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.**

#### DEFICIENCY LIST

1. 2nd Floor - Stairway - SPLC 34.10 (3) 34.33(2) - Provide an approved guardrail. Intermediate balustrade must not be more than 4 inches apart. Intermediate rails must be provided if the height of the platform is more than 30 inches.-Existing guardrail has spacing in excess of 12 inches.
2. 2nd Floor - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)-266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-

Existing double-hung window has an openable area of 19.5 inches high by 27 inches wide. Glazed area of both double-hung panes is a total of 6.7 square feet.

3. Exterior - SPLC 71.01 - The address posted is not visible from street. (HN-1)-Provide reflective numbers or background or illuminate at night.
4. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: [mitchell.imbertson@ci.stpaul.mn.us](mailto:mitchell.imbertson@ci.stpaul.mn.us) or call me at 651-266-8986 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Mitchell Imbertson  
Fire Inspection

Reference Number 109277