



APPLICATION FOR APPEAL

RECEIVED
MAR 07 2011
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____)
- ☒ Copy of the City-issued orders or letter which
are being appealed
- ☐ Attachments you may wish to include
- ☒ This appeal form completed

YOUR HEARING Date and Time:

Tuesday, March 22, 2011

Time 1:30 p.m.

Location of Hearing:

Room 330 City Hall/Courthouse

walk in

Address Being Appealed:

Number & Street: 945 Algonquin Ave City: St Paul State: Mn Zip: 55119

Appellant/Applicant: Daniel Eggers Email debbie.kachler@comcast.net

Phone Numbers: Business _____ Residence _____ Cell 651-442-2399

Signature: [Signature] Date: 3/7/11

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): P.O. Box 6541 St Paul, Mn 55106

Phone Numbers: Business _____ Residence _____ Cell 651-442-2399

What Is Being appealed and why?

Attachments Are Acceptable

- ☐ Vacate Order/Condemnation/
- ☐ Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☒ Fire C of O Deficiency List
- ☐ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other
- ☐ Other
- ☐ Other

height of upper floor for bedroom ceiling
is short 4" this building was
built this way and has always been
used as a bedroom and sold originally
as a bedroom



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

March 3, 2011

DANIEL EGGERS
MARIE E EGGERS
880 PARIS AVE N
STILLWATER MN 55082-2032

RECEIVED

MAR 07 2011

CITY CLERK

FIRE INSPECTION CORRECTION NOTICE

RE: 945 ALGONQUIN AVE
Ref. #115599
Residential Class: A

Dear Property Representative:

Your building was inspected on March 3, 2011 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

A re-inspection will be made on April 4, 2011 at 1:30pm.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. Upper Floor - Ceiling Height - SPLC 34.13 (1) - Provide and maintain all habitable areas with a ceiling height of 7 feet over 1/2 the floor area.

Upper Floor West and East Rooms

Ceiling height is 80 inches = 6 feet, 8 inches.

For an explanation or information on some of the violations contained in this report, please visit our web page at: <http://www.ci.stpaul.mn.us/index.aspx?NID=211>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: wayne.spiering@ci.stpaul.mn.us or call me at 651-266-8993 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Wayne Spiering
Fire Inspector

Reference Number 115599