



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 7-12-11

Time 1:30

Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1044 Hyacinth City: St. Paul State: MN Zip: 55116

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Handwritten Signature] Date: _____

Name of Owner (if other than Appellant): David & Janet Kowitz

Address (if not Appellant's): 1044 Hyacinth Ave E St. Paul MN 55116

Phone Numbers: Business _____ Residence 651-774-5686 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing to replacement casement windows that will not comply w/ St. Paul Egress Policy. Current openings will be short in operable width by 2-1/8". Operable height and overall glazed area is exceeded from the minimum. Please Approve.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: June 22, 2011

APPEAL PROPERTY ADDRESS: 1044 HYACINTH AVE E

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 11 242500

TYPE OF WINDOW Casement

NUMBER OF WINDOWS 2

Total Glazed Area Minimum 5 Square Feet	17 sq.ft.	Difference from Required Area	+12 sq.ft.
Width of Opening Minimum 20 Inches	17 7/8"	Difference from Required Opening	-2 1/8"
Height of Opening Minimum 24 Inches	44.5"	Difference from Required Opening	+20.5"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	OK	Difference from Maximum Height	OK

COMMENTS: Based on information provided above determination to be made by the legislative hearing officer

Reviewed by: jps



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: June 22, 2011

APPEAL PROPERTY ADDRESS: 1044 HYACINTH AVE E

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 11 242500

TYPE OF WINDOW Casement

NUMBER OF WINDOWS 1

Total Glazed Area Minimum 5 Square Feet	8.7 sq.ft.	Difference from Required Area	+3.7 sq.ft
Width of Opening Minimum 20 Inches	18"	Difference from Required Opening	-2"
Height of Opening Minimum 24 Inches	44.5"	Difference from Required Opening	+20.5"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	OK	Difference from Maximum Height	OK

COMMENTS: Based on information provided above determination to be made by the legislative hearing officer

Reviewed by: jps



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: June 22, 2011

APPEAL PROPERTY ADDRESS: 1044 HYACINTH AVE E

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 11 242500

TYPE OF WINDOW Casement

NUMBER OF WINDOWS 3

Total Glazed Area Minimum 5 Square Feet	13.6 sq.ft.	Difference from Required Area	+ 8.6 sq.ft.
Width of Opening Minimum 20 Inches	17 7/8"	Difference from Required Opening	-2 1/8"
Height of Opening Minimum 24 Inches	34.5"	Difference from Required Opening	+10.5"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	OK	Difference from Maximum Height	OK

COMMENTS: Based on information provided above determination to be made by the legislative hearing officer

Reviewed by: jps