

Vang, Mai (CI-StPaul)

From: Neis, Adrian (CI-StPaul)
Sent: Tuesday, October 02, 2012 9:41 AM
To: Vang, Mai (CI-StPaul); Moermond, Marcia (CI-StPaul)
Subject: 1501 York appeal 1 of 2
Attachments: ATT13327.jpg

-----Original Message-----

From: Ubl, Stephen (CI-StPaul)
Sent: Tuesday, October 02, 2012 9:24 AM
To: Neis, Adrian (CI-StPaul)
Subject: FW: IMG00072-20121001-1436.jpg

1501 York (10/01/20112) -

The new (black) roofing material required a permit and inspections. The material was installed improperly. Nails are exposed, edges are not sealed and the roof edge is not trimmed out.

Stephen Ubl
Sr. Building Inspector/Sr. Trades Coordinator Department of Safety & Inspections
375 Jackson St
Saint Paul, MN 55101
P: 651-266-9021
F: 651-266-9099
stephen.ubl@ci.stpaul.mn.us

Making Saint Paul the Most Livable City in America

-----Original Message-----

From: Ubl, Stephen (CI-StPaul)
Sent: Tuesday, October 02, 2012 9:20 AM
To: Ubl, Stephen (CI-StPaul)
Subject: IMG00072-20121001-1436.jpg



