



# APPLICATION FOR APPEAL

RECEIVED  
OCT 08 2010  
CITY CLERK

**Saint Paul City Clerk**  
310 City Hall, 15 W. Kellogg Blvd.  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_) **CHECK PREVIOUSLY MAILED**
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

**YOUR HEARING Date and Time:**

Tuesday, Oct 19  
 Time 1:30  
 Location of Hearing:  
Room 330 City Hall/Courthouse

## Address Being Appealed:

Number & Street: 2061 REANEY AVE City: ST. PAUL State: MN Zip: 55119

Appellant/Applicant: THE HANDYMAN CAN INC  
JOHN THOMAS Email JOHN @ THEHANDYMANCAN.COM

Phone Numbers: Business CELL 651-308-6011 Residence \_\_\_\_\_ Cell \_\_\_\_\_

Signature: [Signature] Date: 10/7/10

Name of Owner (if other than Appellant): ALLISON BOHY

Address (if not Appellant's): \_\_\_\_\_

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell 605-359-2402

## What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

SEE ATTACHED  
"EGRESS WINDOW NON-COM..."  
BY D. NELSON



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

*PER DIVISION INSPECTOR, NASEN*  
*SENT 2500 → CHECK # 12243*  
*TO MAILED 10/6/10*

DATE: October 1, 2010

APPEAL PROPERTY ADDRESS: 2061 REANEY AVE

APPLICANT NAME: HANDYMAN CAN INC

PHONE NUMBER: 651-266-9027

PERMIT NUMBER: 10 614755

TYPE OF WINDOW *Double Hung*  
NUMBER OF WINDOWS *Three (3)*

*SEE JANIE LATRENZ RE ORIG PAPERWORK CHECK*

Total Glazed Area	6.5 sq. ft.	Difference from Required Area	+0.8 sq. ft.
Width of Opening	23"	Difference from Required Opening	+ 3"
Height of Opening	19.5"	Difference from Required Opening	-4.5"
Height of Opening to Finished Floor	Ok	Difference from Maximum Height	

COMMENTS:

Reviewed By : David Nelson