

Moermond, Marcia (CI-StPaul)

From: Martin, Lisa (CI-StPaul)
Sent: Tuesday, November 28, 2017 8:14 AM
To: Moermond, Marcia (CI-StPaul)
Cc: Dornfeld, Matt (CI-StPaul)
Subject: 434 Fry

11/20/17 Met PO on site, found front door no handle, side door does not open, rear yard still has wood and pallets, the egress window now opens in the basement but the water lines on the interior are blocking the egress window. The patio window is shattered and many broken windows, broken sash cords, and missing window locks, had PO remove chain saws with gas from the kitchen, the basement had a dresser and personal belongings, but the bed was gone. Found holes in the chimney in the basement, the plumbing in the basement in the bathroom does not meet code, and the second floor bathroom plumbing to the sink and tub are not working. Hanging light fixture in the bedroom on the second floor, and non-functioning smoke detector. Found extension cords, missing door handles, hanging electric fixtures, the main floor clutter has been removed/the second floor is very cold, the permits have not been approved on the new heating system and all permits still active and not inspected or approved.



Lisa Martin

Inspector III/Code Enforcement Division

Department of Safety and Inspections

375 Jackson St, Suite 220

Saint Paul, MN 55101-1806

P: 651-266-1940

lisa.martin@ci.st.paul.mn.us

“DSI’s Mission: To preserve and improve the quality of life in Saint Paul by protecting and promoting public health and safety for all.”