



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

RECEIVED

AUG 23 2010

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, Sept. 7, 2010

Time 1:30 p.m.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 833 Fremont City: _____ State: _____ Zip: _____

Appellant/Applicant: Stephen Mowry Email: ~~SM~~ mowryst@live.com

Phone Numbers: Business 651-771-0241 Residence _____ Cell _____

Signature: Stephen Mowry Date: _____

Name of Owner (if other than Appellant): PO Box 6513

Address (if not Appellant's): St Paul 55106

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/
- Revocation of Fire C of O _____
- Summary/Vehicle Abatement _____
- Fire C of O Deficiency List _____
- Fire C of O: Only Egress Windows Window 1 1/2" to short (3" wide)
- Code Enforcement Correction Notice _____
- Vacant Building Registration _____
- Other _____
- Other _____
- Other _____



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: August 14, 2010

APPEAL PROPERTY ADDRESS: 833 FREMONT AVE

APPLICANT NAME: STEPHEN L MOWRY

PHONE NUMBER: 651-266-9021

PERMIT NUMBER: 10 609872

TYPE OF WINDOW DBL HUNG

NUMBER OF WINDOWS 1 – Main Level B.R.

RECEIVED
AUG 23 2010
CITY CLERK

Total Glazed Area	7.5 Sq. Ft	Difference from Required Area	+2.5 Sq. Ft
Width of Opening	24"	Difference from Required Opening	+ 4"
Height of Opening	21.5"	Difference from Required Opening	- 2.5"
Height of Opening to Finished Floor		Difference from Maximum Height	

COMMENTS: Recommend approval

Reviewed by: Steve Ubl