



APPLICATION FOR APPEAL

Saint Paul City Council – Legislative Hearings

310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8585

RECEIVED

FEB 10 2015

CITY CLERK

Fee waiver requested for SMRLS

We need the following to process your appeal:

- \$25 filing fee (non-refundable) (payable to the City of Saint Paul) (if cash: receipt number _____)
 - Copy of the City-issued orders/letter being appealed
 - Attachments you may wish to include
 - This appeal form completed
 - Walk-In OR Mail-In
- for abatement orders only: Email OR Fax

HEARING DATE & TIME
(provided by Legislative Hearing Office)
Tuesday, Feb. 17, 2015

Time 11:30 AM

Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 670 5th St E. City: St. Paul State: MN Zip: 55106

Appellant/Applicant: Lavelle Collaso by Lisa Hollingsworth Email: lisa.hollingsworth@smrls.org

Phone Numbers: Business 651.894.6922 Residence _____ Cell _____

Signature: [Signature] Date: 2/10/15

Name of Owner (if other than Appellant): Anna Ovsyannikova & Yevgeniy Ogranovich

Mailing Address if Not Appellant's: 2718 Clare Lane, Mound MN 55364

Phone Numbers: Business _____ Residence _____ Cell 612-229-7009

What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List/Correction
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other (Fence Variance, Code Compliance, etc.)

The tenants moved into the home in August 2014. It has not been damaged by the tenants. They have filed an ETRA with the court. They will be homeless if they cannot stay in the home.



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

January 7, 2015

ANNA OVSYANNIKOVA
2718 CLARE LN
MOUND MN 55364-1812

Revocation of Fire Certificate of Occupancy and Order to Vacate

RE: 670 5TH ST E
Ref. # 117821

Dear Property Representative:

Your building was inspected on January 7, 2015, for the renewal of the Certificate of Occupancy. Since you have failed to comply with the applicable requirements, it has become necessary to revoke the Certificate of Occupancy in accordance with Section 40.06 of the Saint Paul Legislative Code.

A re-inspection will be made on February 9, 2015 at 2:00 pm or the property vacated.

The Saint Paul Legislative Code further provides that no building shall be occupied without a Certificate of Occupancy. Failure to immediately complete the following deficiency list or the building vacated may result in a criminal citation.

DEFICIENCY LIST

1. 2nd Floor - South Bedroom Entry/Exit Door - Ext. Door SPLC 34.09 (3), 34.33 (3) - Repair and maintain the door in good condition.-Install form fitting door. Replace locks on door.
2. 2nd Floor - Water Knob - SPLC 34.11, MSBC 2902.1, SPLC 34.17, MSPC 415.0220 - Repair or replace and maintain all parts of the plumbing system to an operational condition.-Missing water knob on shower wall.
3. Exterior - Garage - SPLC 34.08 (5), 34.31 (3) - Repair, replace and maintain all exterior surfaces on fences, sheds, garages and other accessory structures free from holes and deterioration. Provide and maintain exterior unprotected surfaces painted or protected from the elements.-Repair or replace under HPC approved permit damaged and missing eaves, fascia, soffits and trim throughout garage.

4. Exterior - House - SPLC 34.09 (3), 34.33 (3) -Provide or repair and maintain the window screen.-Repair or replace missing or damaged screens and storm windows.
5. Exterior Repairs - House and Garage - HPC Sec. 73.04(4) Review of permits. The commission shall protect the architectural character of heritage preservation sites through review and approval or denial of applications for city permits for exterior work within designated heritage preservation sites. 670 5th Street East located in the Dayton's Bluff Historic District as described in Sec. 74.76 of the Legislative Code.-Contact HPC, fill out application and submit plans to staff 651.266.6715.
6. First floor - Bathroom - SPLC 34.10 (4), 34.33 (3) - Provide a bathroom floor impervious to water.-
7. Front Door - Aluminum wrap - SPLC 34.09 (1) b,c, 34.33 (1) b, c - Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint.-The trim was falling off of the front door and was blowing in the wind.
8. Garage - Carriage Doors - Ext. Door SPLC 34.09 (3), 34.33 (3) - Repair and maintain the door in good condition.-Replace damaged doors under permit.
9. Garage - Foundation Walls - SPLC 34.08 (5), 34.31 (3) - Repair, replace and maintain all exterior surfaces on fences, sheds, garages and other accessory structures free from holes and deterioration. Provide and maintain exterior unprotected surfaces painted or protected from the elements.-Seal cracks along foundation walls throughout.
10. Garage - Interior Storage - SPLC 34.10 (5), 34.33 (4), 34.16 - Provide and maintain interior in a clean and sanitary condition.-Clean out and remove all scattered trash and debris.
11. Garage - North Door Frames - SPLC 34.09 (3), 34.32 (3) - Repair and maintain the door frame.-Repair or replace damaged hinges and missing screws on both doors.
12. House - Fascia and Eaves - SPLC 34.09 (1) b,c, 34.33 (1) b, c - Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint.-Replace missing east fascia covering along 2nd story arch. Replace and repair missing fascia along west 2nd story and falling eaves along west 2nd story.
13. Interior - Access - SPLC 34.19 - Provide access to the inspector to all areas of the building.-Failure to meet the inspector for the scheduled appointment or failure to contact the inspector to reschedule the scheduled appointment will result in enforcement action. No show for scheduled appointment on 11.4.2014 at 1:15 pm.
14. Interior - East Staircase - SPLC 34.10 (3), 34.33(2) - Repair or replace the unsafe stairway in an approved manner.-Replace all weak and soft staircase steps.

15. Interior - Multiple Areas - SPLC 34.12 (2), SPLC 34.36 (1) - Repair and maintain all required and supplied equipment in an operative and safe condition to properly and safely perform their intended function in accordance with the provisions of the applicable code.
-Replace chirping smoke detector on basement ceiling. Replace missing CO detector batteries. Replace chirping batteries in main floor east bedroom, 2nd floor north bedroom and 2nd floor east bedroom.
16. Kitchen - Floor Tile - SPLC 34.10 (7), 34.34 (6) - Repair and maintain the floor in an approved manner.-Repair or replace the curling and damaged floor tile.
17. Second floor - Bathroom - SPLC 34.11, MSBC 2902.1, SPLC 34.17, MSPC 415.0220 - Repair or replace and maintain all parts of the plumbing system to an operational condition.-The toilet was loose to the floor.
18. West Exterior - Gas Meter - MSFC 603.9- Call Xcel Energy at 1-800-895-4999 to provide vehicle impact protection for the gas meter.-Install impact protection.
19. West Exterior - Wood Staircase - SPLC 34.09 (2), 34.32(2) - Repair or replace the unsafe stairways, porch, decks or railings in an approved manner. This work may require a permit(s). Call DSI at (651) 266-9090.-Replace broken bottom wood staircase step.
20. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
21. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: george.niemeyer@ci.stpaul.mn.us or call me at 651-266-8991 between 7:30 - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.


Sincerely,

George Niemeyer
Fire Inspector

Ref. # 117821



By Order of the
City of Saint Paul
Department of Safety & Inspections
Fire Inspection Division
651-266-8989



REVOCATION NOTICE

The Fire Certificate of Occupancy required for the
Occupancy or Use of This Building, has been Revoked.

It is unlawful to Use or Occupy this building

After: 2/9/2015.

Persons Using or Allowing the Use or Occupancy of
This Building, are Subject to Criminal Penalties.

Building Address: 170 5th St E

Code: SPIC, Art.: 40, Sect. 06.

Inspector: Niemeyer 266-8991, Date 2/9/2015.

Under Penalty of Law, this notice shall not be removed without authorization from the
Department of Safety & Inspections

Any Person affected by this Order, may file an appeal at the Office of the City Clerk,
Room 310, City Hall, 15 Kellogg Blvd. West, or call (651) 266-8688 within 10 days
of the original notice. The cost to file an appeal is \$25, and must include a copy
of the letter of Revocation. This letter of Revocation is available at: Saint Paul Department
of Safety & Inspections, Fire Inspection Division, 375 Jackson Street Suite #220 Saint Paul, MN 55101

KEEP OUT

670 5th St. E

THIS SPACE SHALL NOT BE SEIZED
WITHOUT AUTHORIZATION FROM THE DIVISION
OF CODE ENFORCEMENT

266-1906

T-F 4355

2-10-15

ENFORCEMENT OFFICER

DATE POSTED



NOTICE

REGISTERED VACANT BUILDING

THE CITY OF SAINT PAUL, DEPARTMENT OF SAFETY AND INSPECTIONS, DIVISION OF CODE ENFORCEMENT HAS REGISTERED THE PREMISES LOCATED AT:

670 5th St. E.

AS A VACANT BUILDING IN ACCORDANCE WITH SAINT PAUL LEGISLATIVE CODE, CHAPTER 43, THIS BUILDING SHALL NOT BE SOLD OR OCCUPIED WITHOUT FIRST RECEIVING WRITTEN PERMISSION FROM THE CITY OF SAINT PAUL, DEPARTMENT OF SAFETY AND INSPECTIONS. ANY PERSON HAVING OWNERSHIP RESPONSIBILITY OR FINANCIAL INTEREST IN THIS PREMISES SHOULD CALL THE ENFORCEMENT OFFICER.

CITY OF SAINT PAUL
DSI - CODE ENFORCEMENT
375 JACKSON STREET, SUITE 220
SAINT PAUL, MN 55101-1806
PHONE: (651) 266-8989

THIS NOTICE SHALL NOT BE REMOVED WITHOUT AUTHORIZATION FROM THE DIVISION OF CODE ENFORCEMENT

266-1906 T-F # 353 2-10-15

ENFORCEMENT OFFICER

DATE POSTED

Office Phone: (651) 266-1906
Yog hais nias koj hais lus Hmoob thiab koj tsis to taub tsab ntawv no. hu rau tus txhais lus hawm (651) 266-8989. Nws yog pab dawb zvb.
Si usted habla el Español y no entiende esta nota, llame (651) 266-8989 para un traductor. No costo.