

**LegislativeHearings - RE: 1583 Hazelwood Street**

---

**From:** LegislativeHearings  
**To:** Stoffel, Barry  
**Date:** 11/12/2010 8:01 AM  
**Subject:** RE: 1583 Hazelwood Street  
**CC:** Burger, Kathryn; FireSupervisor; Thomas, James

---

Barry,

In response to your email, Ms. Moermond stated that the extension granted to May 31, 2011 was given at the hearing; therefore, there is no need for additional extension on #8. See below for the rest of the items:

bedroom pic 1 - grant a 7-inch variance on the openable height of the egress bedroom window;  
 bedroom pic 1a - grant a variance on the egress bedroom window;  
 bedroom pic 2 - grant a 7.5-inch variance on the openable height of the egress bedroom window;  
 bedroom pic 2a - grant a variance on the egress bedroom window;  
 laundry room depth of electrical panel from wall - grant a variance;  
 laundry room measurement from dryer to wall at electrical panel - grant a 7-inch clearance;  
 laundry room relocated dryer in front of electrical panel - same - grant a variance on clearance;  
 lower level window - deny on the egress bedroom window. 15" is too short.

Mai Vang  
 Hearing Coordinator  
 651-266-8563

>>> Barry Stoffel <bstoffel@greinerconstruction.biz> 11/10/2010 11:15 AM >>>

Any updates on my questions?

**Barry Stoffel**  
 Project Manager, LEED-AP

**Greiner Construction, Inc.**

Northstar Center West  
 625 Marquette Avenue, Suite 840  
 Minneapolis, MN 55402  
 Direct 612.225.6915  
 Corporate 612.338.1696  
 Mobile 612.366.4274  
 Fax 612.338.1892  
[www.greinerconstruction.biz](http://www.greinerconstruction.biz)

 *Please consider the environment before printing this e-mail*

---

**From:** LegislativeHearings LegislativeHearings [mailto:LegislativeHearings@ci.stpaul.mn.us]  
**Sent:** Tuesday, November 02, 2010 1:31 PM  
**To:** Barry Stoffel  
**Subject:** RE: 1583 Hazelwood Street

yes i have it

>>> Barry Stoffel <bstoffel@greinerconstruction.biz> 11/2/2010 9:42 AM >>>

I just recent the email again. Did you receive it? Your voicemail box is full and I can not leave a voicemail.

**Barry Stoffel**  
Project Manager, LEED-AP

**Greiner Construction, Inc.**

Northstar Center West  
625 Marquette Avenue, Suite 840  
Minneapolis, MN 55402  
Direct 612.225.6915  
Corporate 612.338.1696  
Mobile 612.366.4274  
Fax 612.338.1892  
www.greinerconstruction.biz




---

**From:** LegislativeHearings LegislativeHearings [mailto:LegislativeHearings@ci.stpaul.mn.us]  
**Sent:** Tuesday, November 02, 2010 8:07 AM  
**To:** Barry Stoffel  
**Subject:** Re: 1583 Hazelwood Street

I got a strange email from you and was unable to open. I forwarded your email to our computer tech for their assistance.

Mai

>>> Barry Stoffel <bstoffel@greinerconstruction.biz> 11/1/2010 7:37 PM >>>  
Good evening Mai,

I wanted to follow up to see if you and Marcia received my email with pictures and requests for variances and/or extensions on certain items. Again just wanted to make sure it came through and if so when I may be hearing back on some of the decisions etc.

Thank you!

Barry

---

**From:** LegislativeHearings LegislativeHearings <LegislativeHearings@ci.stpaul.mn.us>  
**To:** Barry Stoffel  
**Sent:** Thu Oct 28 16:16:56 2010  
**Subject:** RE: 1583 Hazelwood Street

Mr. Stoffel,  
Ms. Moermond reviewed your photos and was unable to see the measurements; therefore, please provide clearer photos with the measuring tapes.

Mai Vang

651-266-8563

&gt;&gt;&gt; Barry Stoffel &lt;bstoffel@greinerconstruction.biz&gt; 10/25/2010 8:26 AM &gt;&gt;&gt;

**Barry Stoffel**

Project Manager, LEED-AP

**Greiner Construction, Inc.**

Northstar Center West

625 Marquette Avenue, Suite 840

Minneapolis, MN 55402

Direct 612.225.6915

Corporate 612.338.1696

Mobile 612.366.4274

Fax 612.338.1892

www.greinerconstruction.biz

**From:** LegislativeHearings LegislativeHearings [mailto:LegislativeHearings@ci.stpaul.mn.us]**Sent:** Monday, October 25, 2010 8:26 AM**To:** Barry Stoffel**Subject:** RE: 1583 Hazelwood Street

There is no attachment.

Mai Vang

&gt;&gt;&gt; Barry Stoffel &lt;bstoffel@greinerconstruction.biz&gt; 10/22/2010 2:14 PM &gt;&gt;&gt;

See attached. This is measured from the top of the window sill to the window. You can barely read it. This is for the upstairs windows only. Down stairs has not been double checked yet.

**Barry Stoffel**

Project Manager, LEED-AP

**Greiner Construction, Inc.**

Northstar Center West

625 Marquette Avenue, Suite 840

Minneapolis, MN 55402

Direct 612.225.6915

Corporate 612.338.1696

Mobile 612.366.4274

Fax 612.338.1892

www.greinerconstruction.biz



---

**From:** LegislativeHearings LegislativeHearings [mailto:LegislativeHearings@ci.stpaul.mn.us]  
**Sent:** Thursday, October 21, 2010 2:57 PM  
**To:** Barry Stoffel  
**Subject:** Re: 1583 Hazelwood Street

Hello Mr. Stoffel,

Marcia Moermond, Legislative Hearing Officer, requested that you submit photos showing measurements of the egress windows and photos of the room for the clearance around the electrical panel for her review. You may submit via this email. Thanks.

Mai Vang

Paralegal

266-8563

>>> Barry Stoffel <bstoffel@greinerconstruction.biz> 10/11/2010 2:41 PM >>>

James,

The tenants would like to know if they are allowed to use surge protected extension cords. Can you please advise?

**Barry Stoffel**  
Project Manager, LEED-AP

**Greiner Construction, Inc.**

Northstar Center West  
625 Marquette Avenue, Suite 840  
Minneapolis, MN 55402  
Direct 612.225.6915  
Corporate 612.338.1696  
Mobile 612.366.4274  
Fax 612.338.1892  
[www.greinerconstruction.biz](http://www.greinerconstruction.biz)

