

## Moermond, Marcia (CI-StPaul)

---

**From:** John <john.jagiela@att.net>  
**Sent:** Wednesday, April 3, 2019 10:06 AM  
**To:** Moermond, Marcia (CI-StPaul)  
**Subject:** Re: 134 Montrose Pl.Jagiela Ltr.1-18-19

**Think Before You Click: This email originated outside our organization.**

Hi Ms. Moermond please note I sent the appeal to Steve by separate e mail. John

*Sent from my Verizon Wireless 4G LTE DROID*

"Moermond, Marcia (CI-StPaul)" <marcia.moermond@ci.stpaul.mn.us> wrote:

Mr. Jagiela, Thank you for keeping us in the loop on your Building Code appeal. I am copying Steve Ubl, the City's Building Code Official, as he is the person to whom your appeal should be addressed – per the Building Code appeal form. Best, Marcia Moermond

---

**From:** John Jagiela [mailto:john.jagiela@att.net]  
**Sent:** Tuesday, April 2, 2019 9:24 PM  
**To:** Vang, Mai (CI-StPaul) <mai.vang@ci.stpaul.mn.us>; Moermond, Marcia (CI-StPaul) <marcia.moermond@ci.stpaul.mn.us>; Moynihan, Dan (CI-StPaul) <dan.moynihan@ci.stpaul.mn.us>  
**Cc:** Pieczykolan, Steve (CI-StPaul) <steve.pieczykolan@ci.stpaul.mn.us>; Neis, Adrian (CI-StPaul) <adrian.neis@ci.stpaul.mn.us>; Perucca, James (CI-StPaul) <james.perucca@ci.stpaul.mn.us>; Shaff, Leanna (CI-StPaul) <leanna.shaff@ci.stpaul.mn.us>; Wiese, Angie (CI-StPaul) <angie.wiese@ci.stpaul.mn.us>  
**Subject:** Re: 134 Montrose Pl.Jagiela Ltr.1-18-19

Hi All, Please find attached hereto the Building Code Appeal for 134 Montrose Place and the Order of the Senior Electrical Inspector being appealed.

Also attached hereto is the Sears representation on the Sears Website that all parts including the 10 foot Power Cord are Manufacturer approved

The requirement to obtain a Letter from the Manufacturer of the Washing Machine is unreasonable. Sears sold the Kenmore branded Washing Machine. Sears sells the 10 foot cord. Sears states on its Website that all parts including the 10 foot Power Cord are Manufacturer approved. That should be enough.

Please note that I have filed the Building Code Appeal at the website specified on the Appeal Form.

John

John S. Jagiela  
Attorney at Law  
Native American Finance & Gaming  
Suite 2000  
134 Montrose Place  
St. Paul, Minnesota 55104  
Tel: (651) 646-7277

Cell: (612) 280-6700

**E-Mail:** [john.jagiela@att.net](mailto:john.jagiela@att.net)

On Tuesday, January 22, 2019, 2:05:31 PM CST, Moynihan, Dan (CI-StPaul) <[dan.moynihan@ci.stpaul.mn.us](mailto:dan.moynihan@ci.stpaul.mn.us)> wrote:

Good Afternoon John,

In reference to the second sentence in the below email. This department would require documentation from the manufacturer of the wash machine that would allow the modification to the length of the cord. Most manufacturers would require the purchase of the exact replacement part to maintain the listing of the product. NEC 110.3(B) states "listed and labeled equipment shall be installed and used in accordance with any instructions included in the listing or labeling". A Minnesota Licensed Electrical Contractor can also extend the permanent wiring to the wash machine to reach the cord end, or maybe the wash machine can be moved to reach the receptacle. Hopefully this was helpful.



The Most Livable  
City in America

## Dan Moynihan

### *Senior Electrical Inspector*

Department of Safety and Inspections  
375 Jackson St, Suite 220  
Saint Paul, MN 55101-1806

P: 651-266-9036

[dan.moynihan@ci.stpaul.mn.us](mailto:dan.moynihan@ci.stpaul.mn.us)



Making Saint Paul the Most Livable City in America

***DSI's Mission: "To preserve and improve the quality of life in Saint Paul by protecting and promoting public health and safety for all."***

---

**From:** John Jagiela [<mailto:john.jagiela@att.net>]  
**Sent:** Tuesday, January 22, 2019 11:04 AM  
**To:** Vang, Mai (CI-StPaul) <[mai.vang@ci.stpaul.mn.us](mailto:mai.vang@ci.stpaul.mn.us)>  
**Cc:** Moynihan, Dan (CI-StPaul) <[dan.moynihan@ci.stpaul.mn.us](mailto:dan.moynihan@ci.stpaul.mn.us)>; Pieczykolan, Steve (CI-StPaul) <[steve.pieczykolan@ci.stpaul.mn.us](mailto:steve.pieczykolan@ci.stpaul.mn.us)>; Neis, Adrian (CI-StPaul) <[adrian.neis@ci.stpaul.mn.us](mailto:adrian.neis@ci.stpaul.mn.us)>; Perucca, James (CI-StPaul) <[james.perucca@ci.stpaul.mn.us](mailto:james.perucca@ci.stpaul.mn.us)>; Shaff, Leanna (CI-StPaul) <[leanna.shaff@ci.stpaul.mn.us](mailto:leanna.shaff@ci.stpaul.mn.us)>; Wiese, Angie (CI-StPaul) <[angie.wiese@ci.stpaul.mn.us](mailto:angie.wiese@ci.stpaul.mn.us)>  
**Subject:** Re: 134 Montrose Pl.Jagiela Ltr.1-18-19

Ms. Vang, Please advise Ms. Moermond that I will attend the Legislative Hearing at 1:30 PM today to provide additional information for her consideration.

I can have an electrician install a factory approved 10 foot washer cord and this will then plug in directly to a wall outlet.

I talked to Donnelly Stucco. They advised that there is a new breathable concrete coating that will work fine on the concrete on 134 Montrose Place. So I may decide to use that to repair the peeling paint on the House. John

John S. Jagiela  
Attorney at Law  
Native American Finance & Gaming  
Suite 2000  
134 Montrose Place  
St. Paul, Minnesota 55104  
Tel: (651) 646-7277

Cell: (612) 280-6700

**E-Mail:** [john.jagiela@att.net](mailto:john.jagiela@att.net)

On Friday, January 18, 2019, 10:42:58 AM CST, Vang, Mai (CI-StPaul) <[mai.vang@ci.stpaul.mn.us](mailto:mai.vang@ci.stpaul.mn.us)> wrote:

Hello Mr. Jagiela,

Disregard my first email sent. Attached please find a corrected letter.



**Mai X. Vang**  
***Legislative Hearing Coordinator***  
Saint Paul City Council  
15 W Kellogg Bvd, Ste. 310  
Saint Paul, MN 55102

**P:** 651-266-8563

**F:** 651-266-8574

[mai.vang@ci.stpaul.mn.us](mailto:mai.vang@ci.stpaul.mn.us)

Making Saint Paul the Most Livable City in America