



# APPLICATION FOR APPEAL

RECEIVED  
OCT 14 2011  
CITY CLERK

Saint Paul City Clerk  
310 City Hall, 15 W. Kellogg Blvd.  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR  Mail-In

<b>YOUR HEARING Date and Time:</b>
Tuesday, <u>11-1-11</u>
Time <u>1:30</u>
<b>Location of Hearing:</b>
Room 330 City Hall/Courthouse

## Address Being Appealed:

Number & Street: 1631 Birmingham<sup>St</sup> City: St Paul State: MN Zip: 55106

Appellant/Applicant: Paore Her + Song Lor Email: songlorher@gmail.com

Phone Numbers: Business (651) 235-7334 Residence (651) 815-7288 Cell \_\_\_\_\_

Signature: Paore Her + Song Lor Date: 10/11/11

Name of Owner (if other than Appellant): \_\_\_\_\_

Address (if not Appellant's): \_\_\_\_\_

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell \_\_\_\_\_

## What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

#2, #3, #4, #5 - These windows are the original windows from when the house was built. We did not modify or replace any windows in this house or alter any window structure in the home.



CITY OF SAINT PAUL  
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220  
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989  
Facsimile: 651-266-8951  
Web: [www.stpaul.gov/dsi](http://www.stpaul.gov/dsi)

October 4, 2011

SONG LOR  
9110 EDINBURGH LN  
WOODBURY MN 55125-9189

### FIRE INSPECTION CORRECTION NOTICE

RE: 1631 BIRMINGHAM ST  
Ref. #115196  
Residential Class: C

Dear Property Representative:

Your building was inspected on October 4, 2011 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following **deficiency list. The items on the list must be corrected prior to the re-inspection date. A re-inspection will be made on November 3, 2011 at 10:00 A.M..**

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

**YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.**

#### DEFICIENCY LIST

1. Basement - SPLC 34.10 (7), 34.33 (6) - Repair and maintain the walls in an approved manner.-Repair or replace the damaged or deteriorated wall coverings. Treat walls for mold.
- ② Bedroom N E Side - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout

for more information.-Awning windows 9inches openable height 11inches openable width. Dresser blocking both windows unable to glazed measurements. Sill 45inches

- ③ Bedroom N W Side - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-Awning windows with no hardware. Bed prevents access to measure just the Glazed area.
- ④ Bedroom N W Side - SPLC 34.13 (4) - Provide and maintain a minimum egress window sill height of 48 inches. Refer to provide handout EW-1 for more information.-Sill 56inches
- ⑤ Bedroom South East Side - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-Double hung windows unable to measure dresser blocking windows.
6. ? Garage - SPLC 71.01 - Provide address numbers on building per attached HN-1 handout.
7. ? Garage - SPLC 71.01 - The address posted is not visible from street. (HN-1)-Provide address numbers that contrast with the background. Provide reflective numbers or background or illuminate at night.
8. Garage - SPLC 34.08 (5), 34.31 (3) - Repair, replace and maintain all exterior surfaces on fences, sheds, garages and other accessory structures free from holes and deterioration. Provide and maintain exterior unprotected surfaces painted or protected from the elements.
9. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
10. SPLC 39.02(c) - Complete and sign the provided smoke detector affidavit and return it to this office.
11. SPLC 34.10 (4), 34.33 (3) - Provide a bathroom floor impervious to water.-After securing toilet to floor caulk the base.
12. SPLC 34.11, SBC 2902.1, SPLC 34.17, MPC 415.0220 - Repair or replace and maintain the plumbing fixture to an operational condition.-Repair or replace and maintain an approved private toilet. Secure toilet to floor.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: [james.thomas@ci.stpaul.mn.us](mailto:james.thomas@ci.stpaul.mn.us) or call me at 651-266-8983 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas  
Fire Inspector

Reference Number 115196