



APPLICATION FOR APPEAL

Saint Paul City Clerk
15 W. Kellogg Blvd., 310 City Hall
Saint Paul, Minnesota 55102
Telephone: (651) 266-8688

RECEIVED
OCT 13 2010
CITY CLERK

1. Address of Property being Appealed: <u>1240 Park Street</u>	2. Number of Dwelling Units: <u>SFD</u>	3. Date of Letter Appealed: <u>10-6-10</u>
---	--	---

4. Name of Owner: Tina Gieske
 Address: 1240 PARK ST City: ST. PAUL State: MN Zip: 55117
 Phone Numbers: Business _____ Residence 651-488-1311 Cellular _____
 Signature: _____


5. Appellant / Applicant (if other than owner): Renewal by Andersen
 Address: 1920 W City Rd C City: Roseville State: MN Zip: 55113
 Phone Numbers: Business 651-264-4088 Residence _____ Cellular _____
 Signature: Bryan Horton

6 State specifically what is being appealed and why (Use an attachment if necessary):
We are appealing 3 replacement windows that will not
comply w/ Egress policy. Existing openings will be short by
1'8" in operable height but will exceed operable width
by 4". Please Approve

NOTE: A \$25.00 filing fee made payable to the City of Saint Paul must accompany this application as a necessary condition for filing. You must attach a copy of the original orders and any other correspondence relative to this appeal. Any person unsatisfied by the final decision of the City Council may obtain judicial review by timely filing of an action as provided by law in District Court.

For Office Use Only			
Date Received: <u>10/13/10</u>	Fee Received: <u>25</u>	Receipt Number:	Date of Hearing: <u>Oct 19 11:30</u>

Revised 4/25/2007



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: October 8, 2010

APPEAL PROPERTY ADDRESS: 1240 PARK ST

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-266-9071

PERMIT NUMBER: 10 907628

TYPE OF WINDOW Double hung

NUMBER OF WINDOWS 3

Total Glazed Area	10.3	Difference from Required Area	+5.3
Width of Opening	24	Difference from Required Opening	+4"
Height of Opening	22 7/8	Difference from Required Opening	-1 1/8"
Height of Opening to Finished Floor	36	Difference from Maximum Height	ok

COMMENTS: With the information provided above, approval is recommended. 10-8-10 rr

Reviewed by: Rehn